



## Bid Notice Abstract

### Invitation to Bid (ITB)

**Reference Number** 8672071  
**Procuring Entity** BAGUIO WATER DISTRICT - BAGUIO CITY  
**Title** 2 sets Vertical Centrifugal Pump 550 GPM x 550ft and Motor 100HP  
**Area of Delivery** Benguet

<b>Solicitation Number:</b>	05-035P	<b>Status</b>	<b>Pending</b>
<b>Trade Agreement:</b>	Implementing Rules and Regulations	<b>Associated Components</b>	1
<b>Procurement Mode:</b>	Public Bidding	<b>Bid Supplements</b>	0
<b>Classification:</b>	Goods	<b>Document Request List</b>	0
<b>Category:</b>	Industrial pumps and compressors	<b>Date Published</b>	18/05/2022
<b>Approved Budget for the Contract:</b>	PHP 4,300,000.00	<b>Last Updated / Time</b>	17/05/2022 09:40 AM
<b>Delivery Period:</b>	30 Day/s	<b>Closing Date / Time</b>	01/06/2022 13:30 PM
<b>Client Agency:</b>			
<b>Contact Person:</b>	Ma. Luisa C Tenedero BAC In-House Chairman BWD Compound, Utility Road Baguio City Benguet Philippines 2600 63-74-4424858 63-74-4424858 purchasing.bwd2014@gmail.com		

#### Description

2 sets Vertical Centrifugal Pump and Motor  
Motor Requirement:  
- Type: Induction  
- HP Rating: 100HP  
- Nominal Voltage: 460V  
- Supply Frequency: 60Hz  
- Nominal Speed: 3600 RPM  
- Number of Phase: 3  
- Insulation Class: F  
- Efficiency at full load: not less than 90%  
- Enclose Class: TEFC  
Coupled and aligned with Heavy Duty Mounting Base to:  
Pump Requirement:  
- Capacity: 550 USGPM  
- TDH: 550ft  
Construction Material:  
Shaft Seal: Cartridge Type  
Shaft Seal Material: HQQE  
Pump Head: Stainless Steel  
Pump Shaft: Stainless Steel  
Impeller: Stainless Steel  
Chamber: Stainless Steel  
Outer Sleeve: Stainless Steel  
Base: Cast Iron / Stainless Steel

Neck Ring: PTFE / PEEK  
Support Bearing: NA  
Bearing Rings: NA  
Pump Efficiency: Not less than 75% at rated capacity  
\*For on-site delivery  
\*Supplier to provide BNG & flanges for both suction and discharge ports  
\*Supplier to provide high tensile mounting bolts for pump base  
\*Supplier to provide manufacturer pump test result upon delivery  
\*Supplier to provide brochure with full specification and pump curve of offered booster pump  
Approved budget cost: ₱2,150,000.00 / set

x x x x x

This is a two (2) envelope system:

Envelope "A" to contain the following; among others:


- a) A refundable bid bond in the form of cash, Manager's or Cashier's check equivalent to 2% or surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱ 50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of bids OR Bid Securing Declaration regardless of amount of bid;
- b) Terms of payment, delivery, warranty, bid validity and complete specifications;
- c) Brochure/s (Original);
- d) Proof of payment of a non-refundable fee of ₱5,000.00; otherwise, bids shall not be opened
- e) Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;  
-For bidders who have foreign principal suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement.  
-For locally produced / manufactured products, only certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable;
- f) ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);
- g) International Certificate of Warranty.

Envelope "B" to contain the bid cost per unit.

Pre-bid Conference		
Date	Time	Venue
20/05/2022	9:30:00 AM	Pre-bid conference: May 20, 2022 9:30am via Zoom Application Meeting ID: 452 718 8447 Password: 9Buvqr

**Created by** Ma. Luisa C Tenedero  
**Date Created** 17/05/2022

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.

	<b>BAGUIO WATER DISTRICT</b> <b>BWD Compound, Utility Road, Baguio City 2600</b>	Document No.	ADM-PUR-F003
	<b>REQUEST FOR BIDS/QUOTATION (RQ)</b>	Effectivity Date	February 15, 2020
		Revision No.	00

To: \_\_\_\_\_  
 \_\_\_\_\_  
 (Name of Supplier)

Contact Person: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

Contact no.: \_\_\_\_\_

\_\_\_\_\_

RQ No.: **05 – 035P**

PR / JO No.: **035P**


Date of RQ: **May 12, 2022**

Purpose of RQ:

Amparo Spare booster pump

NOTE: DATA REQUIRED MUST BE FILLED UP COMPLETELY. FAILURE TO INDICATE THE PRICE VALIDITY, TERMS, WARANTY PERIOD AND DELIVERY PERIOD SHALL MEAN OUTRIGHT DISQUALIFICATION OF BIDS				
	Qty.	Description	U-Price	Total
VALIDITY DATE: _____ day <b>(30 days minimum)</b>  DELIVERY: _____ working days _____ calendar days _____ FOB warehouse  WARRANTY _____ calendar days upon acceptance.  TERMS:	2 sets	<b>Vertical Centrifugal Pump and Motor</b> Motor Requirement: - Type: Induction - HP Rating: 100HP - Nominal Voltage: 460V - Supply Frequency: 60Hz - Nominal Speed: 3600 RPM - Number of Phase: 3 - Insulation Class: F - Efficiency at full load: not less than 90% - Enclose Class: TEFC  <b>Coupled and aligned with Heavy Duty Mounting Base to:</b> Pump Requirement: - Capacity: 550 USGPM - TDH: 550ft  Construction Material: Shaft Seal: Cartridge Type Shaft Seal Material: HQQE Pump Head: Stainless Steel Pump Shaft: Stainless Steel Impeller: Stainless Steel Chamber: Stainless Steel Outer Sleeve: Stainless Steel Base: Cast Iron / Stainless Steel Neck Ring: PTFE / PEEK Support Bearing: NA Bearing Rings: NA Pump Efficiency: Not less than 75% at rated capacity  *For on-site delivery *Supplier to provide BNG & flanges for both suction and discharge ports *Supplier to provide high tensile mounting bolts for pump base *Supplier to provide manufacturer pump test result upon delivery *Supplier to provide brochure with full specification and pump curve of offered booster pump  <b>Approved budget cost: ₱2,150,000.00 / set</b> x x x x x		

01 JUN 2022

	<b>BAGUIO WATER DISTRICT</b> <b>BWD Compound, Utility Road, Baguio City 2600</b>		Document No.	ADM-PUR-F003
	<b>REQUEST FOR BIDS/QUOTATION (RQ)</b>		Effectivity Date	February 15, 2020
			Revision No.	00

	<p><b>This is a two (2) envelope system:</b></p> <p><b>Envelope "A" to contain the following; among others:</b></p> <ul style="list-style-type: none"> <li>a) A refundable bid bond in the form of cash, Manager's or Cashier's check equivalent to 2% or surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱ 50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of bids <b>OR</b> Bid Securing Declaration regardless of amount of bid;</li> <li>b) Terms of payment, delivery, warranty, bid validity and complete specifications;</li> <li>c) Brochure/s (Original);</li> <li>d) Proof of payment of a non-refundable fee of <b>₱5,000.00</b>, otherwise bids shall not be opened</li> <li>e) Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;</li> </ul> <p>-For bidders who have foreign principal suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement.</p> <p>-For locally produced / manufactured products, only a certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable;</p> <ul style="list-style-type: none"> <li>f) ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);</li> <li>g) International Certificate of Warranty.</li> </ul> <p><b>Envelope "B" to contain the bid cost per unit.</b></p> <p>Pre-bid conference: <b>20 MAY 2022</b>  9:30am via Zoom Application  Meeting ID: 452 718 8447  Password: 9Buvqr</p>	
--	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--

By: Supplier or Authorized Representative: \_\_\_\_\_ ( sign over printed name )

Deadline of submission of bids: \_\_\_\_\_ **01 JUN 2022** Opening of bids: **1:30 pm**

Prepared by: MGLamangan Noted by: ATTY. MA. LUISA C. TENEDERO ENGR. GUILLERMO V. LUCERO  
PURCHASING BAC IN-HOUSE BAC-TECHNICAL

**BWD RESERVES THE RIGHT TO REJECT BIDS &/OR DECLARE A FAILURE OF BIDDING  
PURSUANT TO THE PERTINENT PROVISIONS OF RA 9184**

Telefax No. (074) 442-4858 (Purchasing) / 444-7246