

## BAGUIO WATER DISTRICT

"Serving Mankind is Serving God"



## BID BULLETIN NO. 1

Request for Quotation (RQ) No. 09-101P Two (2) units 400KVA Brand New Generator Set and One (1) unit 600KVA Brand New Generator Set

This bulletin is issued in response to the query of a prospective bidder with regards to the required rated power during the Pre-Bid Conference held on 07 October 2022:

Required Rating	Prime Rated Power (Minimum)	CLARIFICATION
400KVA	460KVA	The basis of offer should be 400KVA and 600KVA
600KVA	571KVA	respectively but could handle the minimum rated power required for each unit.

All other provisions in the Request for Quotation shall remain to be in full force and effect.

Issued this 12th day of October 2022.

**Bids and Awards Committee:** 

ATTY. MA LUISA C. TENEDERO

Chairperson

ENGR. #ERNANDO A. PERIA

Vice-Chairperson

ATTY. CHANELL DO R D. DE GUZMAN

**CALPITO** 

Member

Member

ENGR. MICHAEL JORDAN E. SISON Member