



## Bid Notice Abstract

### Invitation to Bid (ITB)

**Reference Number** 9672627  
**Procuring Entity** BAGUIO WATER DISTRICT - BAGUIO CITY  
**Title** Various Soft Starter Motor Controller  
**Area of Delivery** Benguet

<b>Solicitation Number:</b> 03-053P	<b>Status</b>	<b>Pending</b>
<b>Trade Agreement:</b> Implementing Rules and Regulations	<b>Associated Components</b>	1
<b>Procurement Mode:</b> Public Bidding	<b>Bid Supplements</b>	0
<b>Classification:</b> Goods	<b>Document Request List</b>	0
<b>Category:</b> Industrial pumps and compressors	<b>Date Published</b>	19/04/2023
<b>Approved Budget for the Contract:</b> PHP 2,040,000.00	<b>Last Updated / Time</b>	18/04/2023 15:19 PM
<b>Delivery Period:</b>	<b>Closing Date / Time</b>	10/05/2023 13:30 PM
<b>Client Agency:</b>		
<b>Contact Person:</b> Ma. Luisa C Tenedero BAC In-House Chairman BWD Compound, Utility Road Baguio City Benguet Philippines 2600 63-74-4424858 63-74-4424858 purchasing.bwd2014@gmail.com		

#### Description

6 units Soft Starter Motor Controller  
 Capacity of Motor to be Controlled by the Soft Starter  
 Motor rating: 60HP  
 Motor voltage rating: 460V  
 Supply frequency: 60Hz  
 Number of Phase: 3  
 Speed (nominal): 3600Rpm  
 Approved Budget Cost: ₱170,000.00 / unit

2 units Soft Starter Motor Controller  
 Capacity of Motor to be Controlled by the Soft Starter  
 Motor rating: 40HP  
 Motor voltage rating: 460V  
 Supply frequency: 60Hz  
 Number of Phase: 3  
 Speed (nominal): 3600Rpm  
 Approved Budget Cost: ₱150,000.00 / unit

6 units Soft Starter Motor Controller  
 Capacity of Motor to be Controlled by the Soft Starter  
 Motor rating: 20HP  
 Motor voltage rating: 460V



Supply frequency: 60Hz  
 Number of Phase: 3  
 Speed (nominal): 3600Rpm  
 Approved Budget Cost: ₱120,000.00 / unit

**Soft Starter Specifications:**

1 Main Voltage  
 L1, L2, L3 200VAC – 300VAC (+/-10%)

2 Control Voltage  
 (A4, A6) 220-240VAC (+10% / -15%)  
 Main Frequency 60Hz (+/- 10%)  
 Rated insulation voltage to earth: 600VAC  
 Rated impulse withstand voltage: 4kV

3 Short Circuit Capability  
 Coordination Semi-conductor fuses  
 Prospective current 65kA

4 Outputs  
 Relay outputs 10A @ 250VAC resistive  
 Programmable outputs 1 (NC), 1 (NO), 1 (CO)  
 Analogue outputs 4-20mA  
 Maximum load 600Ω (12VDC @ 20mA accuracy +/-5%)

24VDC output, maximum load: 200mA (accuracy +/- 10%)

5 Environmental  
 Protection IP20 & NEMA, UL  
 Operating temperature -10°C to 60°C  
 Storage temperature -25°C to 60°C

6 Heat Dissipation  
 During start 4.5 watts per ampere  
 Soft Starter should be equipped with SCADA ready device  
 - Bidder to submit a certificate of sole distributorship  
 - Supplier to be present during testing /commissioning

x x x x x

Note: not to be awarded on a one (1) lot basis.

This is a two (2) envelope system:

Envelope "A" to contain the following, among others:

- a) A refundable bid bond in the form of cash, Manager's or Cashier's check equivalent to 2% or a surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱ 50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of bids OR Bid Securing Declaration regardless of the amount of bid;
- b) Terms of payment, delivery, warranty, bid validity, and complete specifications;
- c) Brochure/s (Original);
- d) Proof of payment of a non-refundable fee of ₱5,000.00; otherwise, bids shall not be opened
- e) Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;  
 -For bidders who have principal foreign suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement.  
 -For locally produced/manufactured products, only a certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable;
- f) ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);
- g) International Certificate of Warranty.

Envelope "B" to contain the bid cost per unit.

**Pre-bid Conference**

Date	Time	Venue
28/04/2023	9:30:00 PM	Pre-bid conference: April 28, 2023 9:30 am via Zoom Application

Meeting ID: 452 718 8447

Password: 9Buvqr

**Created by** Ma. Luisa C Tenedero**Date Created** 18/04/2023

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.

© 2004-2023 DBM Procurement Service. All rights reserved.

[Help](#) | [Contact Us](#) | [Sitemap](#)







<b>BAGUIO WATER DISTRICT</b> <b>BWD Compound, Utility Road, Baguio City 2600</b>		Document No.	ADM-PUR-F003
<b>REQUEST FOR BIDS/QUOTATION (RQ)</b>		Revision Date	February 15, 2020
		Revision No.	01

To: \_\_\_\_\_  
(Name of Supplier)

Contact Person: \_\_\_\_\_

Address: \_\_\_\_\_

Contact no.: \_\_\_\_\_

RQ No.: **03 – 053P**

PR / JO No.: **053P**

Date of RQ: **March 30, 2023**

Purpose of RQ:  
For upgrade of controls of submersible pumps

NOTE: DATA REQUIRED MUST BE FILLED UP COMPLETELY. FAILURE TO INDICATE THE PRICE VALIDITY, TERMS, WARRANTY PERIOD AND DELIVERY PERIOD SHALL MEAN OUTRIGHT DISQUALIFICATION OF BIDS				
	Qty.	Description	U-Price	Total
<b>VALIDITY DATE:</b> _____ day <b>(30 days minimum)</b>	<b>6 units</b>	<b>Soft Starter Motor Controller</b> Capacity of Motor to be Controlled by the Soft Starter Motor rating: <b>60HP</b> Motor voltage rating: <b>460V</b> Supply frequency: <b>60Hz</b> Number of Phase: <b>3</b> Speed (nominal): <b>3600Rpm</b> Approved Budget Cost: ₱170,000.00 / unit		
<b>DELIVERY :</b> _____ working days _____ calendar days _____ FOB warehouse	<b>2 units</b>	<b>Soft Starter Motor Controller</b> Capacity of Motor to be Controlled by the Soft Starter Motor rating: <b>40HP</b> Motor voltage rating: <b>460V</b> Supply frequency: <b>60Hz</b> Number of Phase: <b>3</b> Speed (nominal): <b>3600Rpm</b> Approved Budget Cost: ₱150,000.00 / unit		
<b>WARRANTY</b> _____ calendar days upon acceptance.	<b>6 units</b>	<b>Soft Starter Motor Controller</b> Capacity of Motor to be Controlled by the Soft Starter Motor rating: <b>20HP</b> Motor voltage rating: <b>460V</b> Supply frequency: <b>60Hz</b> Number of Phase: <b>3</b> Speed (nominal): <b>3600Rpm</b> Approved Budget Cost: ₱120,000.00 / unit  Soft Starter Specifications: 1 Main Voltage L1, L2, L3 200VAC – 300VAC (+/-10%) 2 Control Voltage (A4, A6) 220-240VAC (+10% / -15%) Main Frequency 60Hz (+/- 10%) Rated insulation voltage 600VAC to earth Rated impulse withstand 4kV voltage 3 Short Circuit Capability Coordination Semi-conductor fuses Prospective current 65kA 4 Outputs Relay outputs 10A @ 250VAC resistive Programmable outputs 1 (NC), 1 (NO), 1 (CO) Analogue outputs 4-20mA Maximum load 600Ω (12VDC @ 20mA accuracy +/-5%) 24VDC output, maximum 200mA (accuracy +/- 10%) load 5 Environmental Protection IP20 & NEMA, UL indoor type 1		
<b>TERMS:</b>				

Smei



01