



BAGUIO WATER DISTRICT
"Serving Mankind is Serving God"

003 Purok BWD, Brgy., Marcoville, Baguio City
Tel. No. 442-4858 Fax No. 442-4858/444-7245

Document No.:	ADM-PUR-F006
Effectivity Date:	February 15, 2020
Revision No.:	00

Nº 035264

PURCHASE ORDER

MAY 12 2023

Supplier : P. T. CERNA CORPORATION	P.O. No. : 35264
Tel./No./ Fax No. : (02) 890-2802	Date : May 10, 2023
Address / TIN : 4137 Ponte St., Brgy. Sta. Cruz, Makati City	PR No./Abstract No. : 05-117P-R

Gentlemen/ Madam,

Please furnish this Office the following articles subject to the terms and conditions contained herein.

Place of Delivery : <input type="checkbox"/> Pick up <input checked="" type="checkbox"/> FOB BWD Warehouse <input type="checkbox"/> Deliver at site	P.O. Valid Until : 30 days Warranty : <input type="checkbox"/> Six months <input checked="" type="checkbox"/> One year <input type="checkbox"/> Others (Pls. Specify) against Factory Defect
Date of Delivery : <input type="checkbox"/> Working days 12-18 weeks <input type="checkbox"/> Calendar Days upon receipt of PO	<input checked="" type="checkbox"/> 1% Retention Required <input type="checkbox"/> Performance Bond Required (5% if in check/50% if GSIS surety bond)
Delivery Term : <input type="checkbox"/> full <input type="checkbox"/> partial delivery allowed	<input checked="" type="checkbox"/> Subject to testing / inspection prior to payment Payment Term : <input type="checkbox"/> COD <input checked="" type="checkbox"/> 30 Days <input type="checkbox"/> Others (Pls. Specify)

Quantity	Unit	Description/Specifications	Unit Cost	Amount
1	set	8" Electromagnetic Flow Meter Make: Badger Model: 5M-A-080-FAA-C1-H-A-A-S-RA-AF-A-MD-XBA-S-XX-AA-ED-F x x x x (Please refer to the attached sheet for complete detailed specifications)		P 657,000.00

Usage / Requisitioner **Construction of DMA measuring points c/o Engr. S.F.Manangan**

Prepared by:

Checked by:

Audited by:

Recommending Approval:

Approved By:

MARCOS G. LAMANGAN **ATTY. CHANELL DOLOR D. DE GUZMAN**

LUZVIMIN G. RAMOS

ATTY. MA. LUISA TENEDERO

ENGR. SALVADOR M. ROYECA

Purchasing Supervisor

Admin Division Manager

Internal Auditor

AGM-Adm./Com./Fin.

General Manager

Conforme:

Signature over Printed Name of Supplier

Date

Funds Available:

JELYN D. PENALES




Finance Manager

Acct. :

Operating / Maintenance Expense ☐

CAPEX ☒

Other Payables ☐

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600	Document No.	ADM-PUR-F006
	PURCHASE ORDER (P.O.)	Revision Date	February 15, 2020
	Revision No.	00	

Supplier/Contractor	: P.T. CERNA CORPORATION	Purchase Order No.	: 35264
Contact Number	: (02) 519-6214 / 890-2802 (FAX)	Date	: May 10, 2023
Address / TIN	: 4137 Ponte St., Brgy. Sta Cruz, Makati City	PR No./Abstract No.	: 05-117P-R

Qty	Unit	Description	Unit Cost	Amount
1	set	8" Electromagnetic Flow Meter, Make: Badger	657,000.00	657,000.00
		Model: 5M-A-080-FAA-C1-H-A-A-S-RA-AF-A-MD-XBA-S-XX-AA-ED-F		
		Specifications:		
		1 EA Battery powered, with battery life up to 20 years		
		- ±0.4% of measured value ±2mm/s accuracy independent of fluid		
		Viscosity, density, and temperature		
		- Unaffected by most solids contained in fluids		
		- LCD Display		
		- Pulsed DC magnetic field for zero-point stability		
		- No pressure loss for low operational cost		
		- Corrosion resistant liners for long life		
		- Calibrated in state-of-the-art facilities		
		- Integral and remote signal converter availability		
		- Optional grounding rings or grounding electrode		
		- Measurement largely independent of flow profile		
		- Low power digital microcontroller (16 bit)		
		- Simple programming procedure		
		- Digital and infrared outputs		
		- Automatic zero-point stability		
		- Non-volatile programming		
		- NSF/ ANSI/ CAN 61 and 372, OIML, MID and AWWA C715		
		certified		
		- Data Logging		
		- Verification device		
		- IP67/ IP68 protection class		
		- Modbus RTU (RS232), IRDA, M-Bus, optional Modbus RTU		
		(RS 485)		
		- BEACON / AquaCUE connectivity		
		**Including: Start-up and Commissioning		

Total: ₱657,000.00

Usage: Construction of DMA measuring points c/o Engr. S.F.Manangan


Prepared by:


Checked by:


Audited by:


Recommending
Approval:


Approved by:



M. G. Lamangan
SMPO


Atty. C.D. De Guzman
Administrative Div. Manager


L. G. Ramos
Internal Auditor


Atty. M. C. Tenedero
AGM Adm./Com./Fin./ICT


Engr. Salvador M. Royeca
General Manager

	BAGUIO WATER DISTRICT Bids and Awards Committee (In-house)	Document Code: BAC_IH
		Document No. BAC_IH_F002
		Effective Date: 16 March 2020
	RESOLUTION	Revision No. 00

**BIDS AND AWARDS COMMITTEE
RESOLUTION NO.022-2023**
 (RQ No. 02-117P-R: Electronic Flow Meter)

WHEREAS, the Baguio Water District-Bids and Awards Committee (BWD-BAC), in accordance with the provisions of Republic Act (RA) No. 9184, conducted the re-bidding for the procurement of one (1) set 8" electronic flow meter, with required specifications under Request for Quotation (RQ) No. 02-117P-R dated 23 February 2023 under a two-envelope system of bidding;

WHEREAS, the approved budget cost for the said item is Php763,470.00/set;








WHEREAS, FANM ENTERPRISES, INC. and P.T. CERNA CORPORATION submitted their bids and during the opening of the technical bids on 15 March 2023, it was determined that both bidders submitted complete documentary requirements; thus, their bids were subjected to TWG evaluation;

WHEREAS, upon evaluation by the Technical Working Group of the offers of both bidders, it was determined that they both submitted complying bids thus, their financial bids were opened on 11 April 2023 and the bids as read and calculated are as follows:

NAME OF BIDDERS	BRAND	BID AS READ AND CALCULATED (set)	% VARIANCE FROM ABC	ABC (set)
FANM ENTERPRISES, INC.	Siemens AG	Php763,470.00	-0-	Php763,470.00
P.T. CERNA CORPORATION	Badger Meter	Php657,000.00	13.95%	Php763,470.00


WHEREAS, upon qualification and careful examination, validation and verification of all the documents submitted by and of the financial bids of the complying bidders, it has been determined that **P.T. CERNA CORPORATION** submitted complete documents and its financial bid for one (1) set 8" electronic flow meter is determined the lowest calculated responsive bid;


NOW THEREFORE, on motion duly seconded, be it










RESOLVED, as it is hereby resolved, to recommend to the Head of Procuring Entity (HOPE) the awarding of the procurement of one (1) set 8" electronic flow meter to **P.T. CERNA CORPORATION** with the offered brand and specifications for being the lowest calculated responsive bidder in this particular re-bidding.


UNANIMOUSLY APPROVED (20 April 2023)



Engr. Fernando A. Peria
Vice-Chairperson



Engr. Reynant I. De Torres
Member


Engr. Noriel C. Calpito
Member



Engr. Michael Jordan E. Sison
Member



Engr. Shayne Margie S. Abellera
Member


Geovani L. Piza
Member



Atty. Ma. Luisa C. Fenedero
Chairperson

Attested by the Secretariat:


Apple Jane P. Aviles


Sharlene M. Durante

Approved by:


Engr. Salvador M. Royeca
General Manager