



BAGUIO WATER DISTRICT

"Serving Mankind is Serving God"

003 Purok BWD, Brgy., Marcoville, Baguio City
Tel. No. 442-4858 Fax No. 442-4858/444-7245

Document No.: ADM-PUR-F006
Effectivity Date: February 15, 2020
Revision No.: 00

Nº 035375

PURCHASE ORDER

Supplier : KEYLARGO INDUSTRIAL SALES	P.O. No. : 35375
Tel No./ Fax No. : 02-284-2856 / 961-52-60 local 218	Date : June 27, 2023
Address / TIN : 1471 Quezon Ave. West Triangle Q.C.	PR No./Abstract No. : 05-044 P

Gentlemen/ Madam,

Please furnish this Office the following articles subject to the terms and conditions contained herein.

Place of Delivery : <input type="checkbox"/> Pick up <input checked="" type="checkbox"/> FOB BWD Warehouse <input type="checkbox"/> Deliver at site	P.O. Valid Until : 30 days Warranty : <input type="checkbox"/> Six months <input checked="" type="checkbox"/> One year <input type="checkbox"/> Others (Pls. Specify)
Date of Delivery : <input type="checkbox"/> Working days 4-5 weeks <input type="checkbox"/> Calendar Days upon receipt of PO	<input checked="" type="checkbox"/> 1% Retention Required <input type="checkbox"/> Performance Bond Required (5% if in check/50% if GSIS surety bond)
Delivery Term : <input type="checkbox"/> full <input type="checkbox"/> partial delivery allowed	<input checked="" type="checkbox"/> Subject to testing / inspection prior to payment Payment Term : <input type="checkbox"/> COD <input checked="" type="checkbox"/> 30 Days <input type="checkbox"/> Others (Pls. Specify)

Quantity	Unit	Description/Specifications	Unit Cost	Amount
1	set	<p>"Grundfos" (Denmark) Model: SP215-2 Submersible Deepwell Pump, 1000 GPM x 250 feet TDH, 85% efficiency, 3600RPM, 8" Ø std dia.</p> <p>COUPLED TO:</p> <p>"Franklin" (USA) Submersible Motor, 125HP, 460Volts, 3 phase, 8"Ø, Plug-in or detachable Lead Wires, NEMA Standard</p> <p style="text-align: center;">x x x x</p> <p>(Please refer to the attached sheet for complete detailed specifications)</p> <p>- Maximum Diameter: 8"</p> <p>- Supplier to provide manufacturer pump test result upon delivery</p> <p>- Supplier to provide brochure with full specification and pump curve of offered booster pump</p>	1,500,000.00 ₱	1,500,000.00

For spare pump and motor c/o Engr. JBPamaylaon

Usage / Requisitioner

Prepared by: MARCOS G. LAMANGAN Purchasing Supervisor
Checked by: ATTY. CHANELL DOLOR D. DE GUZMAN Admin Division Manager
Audited by: LUZVIMIN G. RAMOS Internal Auditor
Recommending Approval: ATTY. MA. LISA C. TENEDERO AGM-Adm./Com./Fin.
Approved By: ENGR. SALVADOR M. ROYECA General Manager

Conforme:

Signature over Printed Name of Supplier

Date

Funds Available:

JELYN D. PENALES




Finance Manager

Acct. :

Operating / Maintenance Expense ☐




CAPEX ☒




Other Payables ☐

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600		Document No.	ADM-PUR-F006
	PURCHASE ORDER (P.O)		Revision Date	February 15, 2020
			Revision No.	00

Supplier/Contractor	: KEYLARGO INDUSTRIAL SALES	Purchase Order No.	: 35375
Contact Number	: 02-248-2856/961-52-60 local 218	Date	: June 20, 2023
Address / TIN	: 1471 Quezon Ave. West Triangle Quezon City	PR No./Abstract No.	: 06-044P

Qty	Unit	Description	Unit Cost	Amount
1	set	<p>"Grundfos" (Denmark) Submersible Deepwell Pump Model: SP215-2 rated to deliver 1000 GPM (227.12 cu.m/hr) against 250 feet (76.2meters) with 85% efficiency</p> <p>I. General Requirements:</p> <p>Capacity: 1000 GPM</p> <p>TDH: 250 feet</p> <p>Eff. @ Rated Capacity: 85%</p> <p>Speed (Nominal): 3600 rpm</p> <p>Discharge Nipple with coupling: 12" Schedule 80, BI</p> <p>Standard diameter: 8 inches</p> <p>Check valve and Strainer:</p> <ul style="list-style-type: none"> - Standard built-in stop ring to prevent upthrust damage during critical start up and stopping phase - Capable to handle sand content from 50 to 150ppm on certain pump sizes. - Coupling: NEMA Standard Spline Type <p>II. Material Components:</p> <p>Valve Casing: Stainless Steel</p> <p>Valve Cup: Stainless Steel</p> <p>Neck ring:</p> <ul style="list-style-type: none"> For pump capacity: 1-5 cum/hr: NBR/TPU For pump capacity: 7-14 cum/hr: TPU/PPS-FKM For pump capacity: 17-60 cum/hr: NBR-FKM-LSR For pump capacity: 77 cum & above NBR-FKM <p>Bearing:</p> <ul style="list-style-type: none"> - Replaceable wear ring, bearing and neck ring for easy maintenance. - Sealed top bearing for high resistance against sand - Octagonal shape bearings with sand flush channels to reduce abrasive wear <ul style="list-style-type: none"> For pump capacity: 1-5 cum/hr: NBR For pump capacity: 7-14 cum/hr: LSR-FKM For pump capacity: 17-60 cum/hr: NBR-FKM For pump capacity: 77 cum & above NBR-FKM <p>Chamber: Stainless Steel</p> <p>Impeller: Stainless Steel</p> <p>Suction interconnector: Cast Stainless Steel</p> <p>Shaft complete: Stainless Steel</p> <p>Strap: Stainless Steel</p> <p>Cable guard: Stainless Steel</p> <p>Washer for stop ring: Carbon / Graphite HY22 in PTEE mass</p> <p>Strainer: Stainless Steel</p> <p>Valve seat:</p> <ul style="list-style-type: none"> For pump capacity: 1-5 cum/hr: Rubber Type/NBR For pump capacity: 7-14 cum/hr: NBR-FKM For pump capacity: 17-60 cum/hr: NBR-FKM For pump capacity: 77 cum & above NBR-FKM <p>III. Others:</p> <p>Discharge nipple: 6" Ø x 8" x 12", S-40, BI</p> <p>Discharge coupling: 8" Ø, S-80, BI or SS</p>	1,500,000.00	1,500,000.00

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600		Document No.	ADM-PUR-F006
	PURCHASE ORDER (P.O)		Revision Date	February 15, 2020
			Revision No.	00

Qty	Unit	Description	Unit Cost	Amount
		IV. Must submit the authenticated certificate of dealership/distributorship with a red ribbon		
		V. ISO certified		
		Coupled and aligned with Heavy Duty Mounting Base to:		
		"Franklin" (USA) Submersible Motor		
		Submersible Motor features as follow:		
		I. General Requirements:		
		Rating: 125HP		
		Nominal Voltage (V): 460 Volts		
		Number of Phase: 3		
		Frequency: 60Hz.		
		Std. Diameter: 8 inches		
		Lead Wire / Cables: Plug-in or Detachable		
		Rotor Spline: NEMA Standard		
		II. Material Components for standard water well 8" Ø Standard		
		End Castings: Gray Iron		
		Stator Shell: 301 SS		
		Stator Ends: Low Carbon Steel		
		Shaft Extension: 17-4 SS (40-60HP)		
		Fasteners: 300 & 400 Series SS		
		Seal Cover: 304 SS & Sintered Bronze		
		Seal: Carbon Ceramic Face		
		Diaphragm: Nitrile		
		Diaphragm Plate: 304 SS		
		Diaphragm Spring: 302 SS		
		Diaphragm Cover: 304D		
		Slinger: Nitrile		
		Lead Wire (or Cable): XLPE 125°C		
		Lead Potting: Epoxy		
		Lead Jam Nut:		
		Filter: Delrin & Polyester		
		III. Must submit the authenticated certificate of dealership/distributorship with a red ribbon		
		IV. ISO certified		

Total: ₱1,500,000.00

Usage: For spare pump and motor c/o Engr. JBPamaylaon


Prepared by:


Checked by:


Audited by:


Recommending
Approval:

Approved by:





M. G. Lamangan
SMPO


Atty. C.D. De Guzman
Administrative Div. Manager


L. G. Ramos
Internal Auditor


Atty. M.L.C. Tenedero
AGM Adm./Com./Fin./ICT


Engr. Salvador M. Royeca
General Manager

  	BAGUIO WATER DISTRICT Bids and Awards Committee (In-house)		Document Code: BAC_IH
			Document No. BAC_IH_F002
			Effective Date: 16 March 2020
	RESOLUTION		Revision No. 00

**BIDS AND AWARDS COMMITTEE
RESOLUTION NO.042-2023
(RQ No. 03-044P: Submersible Pump and Motor)**

WHEREAS, the Baguio Water District-Bids and Awards Committee (BWD-BAC), in accordance with the provisions of Republic Act (RA) No. 9184, conducted the bidding for the procurement of one (1) set 1000gpm submersible pump coupled to a 125Hp submersible motor with the required specifications under Request for Quotation (RQ) No. 03-044P dated 30 March 2023, under a two-envelope system of bidding;

WHEREAS, the approved budget unit cost for the said procurement is Php1,500,000.00/set;

WHEREAS, only **KEYLARGO INDUSTRIAL SALES** submitted its bids and during the opening of technical bids on 10 May 2023, it was determined that said bidder submitted complete documentary requirements;

WHEREAS, upon evaluation by the Technical Working Group of the offers of the lone complying bidder, it was determined that it submitted complying bids thus, its financial bid was opened on 07 June 2023 and the bid as read and calculated is as follows:

NAME OF BIDDER	BRAND	BID AS READ AND CALCULATED (per set)	% VARIANCE FROM ABC	ABC (per set)
KEYLARGO INDUSTRIAL SALES • 1000gpm submersible pump coupled to a 125Hp submersible motor	Grundfos/ Franklin	Php1,500,000.00	-0-	Php1,500,000.00

WHEREAS, upon qualification and careful examination, validation and verification of all the documents submitted by and of the financial bids of the complying bidder, it has been determined that **KEYLARGO INDUSTRIAL SALES** submitted complete documents and its financial bids are determined to be the lone calculated responsive bids for each respective equipment;

NOW THEREFORE, on motion duly seconded, be it

RESOLVED, as it is hereby resolved, to recommend to the Head of Procuring Entity (HOPE) awarding the procurement of one (1) set 1000gpm submersible pump coupled to a 125Hp submersible motor to **KEYLARGO INDUSTRIAL SALES** with the offered brands and specifications for being the lone calculated responsive bidder.

UNANIMOUSLY APPROVED (07 June 2023)

Engr. Fernando A. Peria
Vice-Chairperson

Engr. Reynant I. De Torres
Member

Engr. Noriel C. Calpito
Member

Engr. Michael Jordan E. Sison
Member

Engr. Shayne Margie S. Abellera
Member

Geovani L. Piza
Member

Atty. Ma. Luisa C. Tenedero
Chairperson

Attested by the Secretariat:

Apple Jane E. Aviles

Sharlene M. Durante

Approved by:

Engr. Salvador M. Royeca
General Manager