



BID BULLETIN NO. I

Request for Quotation (RQ) No. 10-048P-N

Two (2) sets Submersible Pump, 25gpm coupled
to Submersible Motor, 5Hp
Two (2) sets Submersible Pump, 20gpm coupled to
Submersible Motor, 5Hp

This bulletin is issued to amend the specifications for the above-mentioned Request for Quotation:

QUANTITY	ITEM/REQUIREMENT	AMENDMENT
2 sets	Submersible Pump Capacity: 25 gpm TDH: 400 ft Eff.@ Rated Capacity: 65% minimum Speed (Nominal): 3600 rpm Discharge Nipple with coupling: 12" Schedule 80, BI Diameter of Nipple and Coupling will depend on the discharge port Coupled to: Submersible Motor Rating: 5 Hp Nominal Voltage: 230V Number of Phase: Single Phase Frequency: 60 Hz	No amendment
2 sets	Submersible Pump Capacity: 20 gpm TDH: 400 ft Eff.@ Rated Capacity: 65% minimum Speed (Nominal): 3600 rpm Discharge Nipple with coupling: 12" Schedule 80, BI Diameter of Nipple and Coupling will depend on the discharge port Coupled to: Submersible Motor Rating: 5 Hp Nominal Voltage: 460V Number of Phase: Single Phase Frequency: 60 Hz	Submersible Pump Capacity: 20 gpm TDH: 400 ft Eff.@ Rated Capacity: 65% minimum Speed (Nominal): 3600 rpm Discharge Nipple with coupling: 12" Schedule 80, BI Diameter of Nipple and Coupling will depend on the discharge port Coupled to: Submersible Motor Rating: 5 Hp Nominal Voltage: <u>230V</u> Number of Phase: Single Phase Frequency: 60 Hz


All other requirements in the Request for Quotation shall remain to be in full force and effect.


For guidance and information of all concerned.

Issued this 8th day of November 2023.


Bids and Awards Committee:


ENGR. NORIEL C. CALPITO
Vice-Chairperson


ATTY. MA LUISA C. TENEDERO
Chairperson


RODRIGO G. DE VENECIA, JR.
Member


ENGR. DOMINIC T. AGUSDAN
Member


ROMEO S. ADRIANO
Member


ATTY. FRANCES LOUISE E. GENER
Member


ENGR. SHAYNE MARGIE S. ABELLERA
Member