



Bid Notice Abstract

Invitation to Bid (ITB)

Reference Number 10444661
Procuring Entity BAGUIO WATER DISTRICT - BAGUIO CITY
Title 2 sets Submersible Pump, 2 units Soft Starter, & 2 units Variable Frequency Drive - Richview & South Drive DW
Area of Delivery Benguet

Solicitation Number: 12-231P-D	Status	Pending
Trade Agreement: Implementing Rules and Regulations	Associated Components	1
Procurement Mode: Public Bidding	Bid Supplements	0
Classification: Goods	Document Request List	0
Category: Industrial pumps and compressors	Date Published	23/12/2023
Approved Budget for the Contract: PHP 2,500,000.00	Last Updated / Time	22/12/2023 09:35 AM
Delivery Period:	Closing Date / Time	10/01/2024 13:30 PM
Client Agency:		
Contact Person: Ma. Luisa C Tenedero Chairperson, Bids and Awards Committee BWD Compound, Utility Road Baguio City Benguet Philippines 2600 63-74-4424858 63-74-4424858 purchasing.bwd2014@gmail.com		

Description
2 sets Submersible Pump Capacity : 150 gpm TDH : 500 ft Eff. @ Rated Capacity : Not less than 65% Speed (Nominal) : 3600 rpm Nominal Discharge Nipple with coupling : 12" Schedule 80, BI Diameter of Nipple and Coupling will depend on the discharge port Coupled to: Submersible Motor Rating : 30 Hp Nominal Voltage : 460 V Number of Phase : 3 Phase Frequency : 60 Hz (please refer to attached for complete specifications) *Maximum Diameter: 6 inches *Supplier to provide manufacturer pump test result upon delivery *Supplier to provide brochure with full specification and pump curve of offered booster pump Approved Budget Cost: ₱ 520,000.00 / unit
2 units Soft Starter Adaptable to 30HP, 460V nominal, 3600 rpm nominal, 3 phase, 60Hz submersible motor Approved Budget Cost: ₱ 180,000.00 / unit * Supplier to be present during testing commissioning
2 units Variable Frequency Drive Adaptable to 50 HP, 460V, 3 phase, 60Hz submersible motor Capacity of pressure transmitter: 0-25 bars Control Body: IP 65 rated minimum With connection-based monitoring

