



PhilGEPS

Philippine Government Electronic Procurement System

Central Portal for
Philippine Government
Procurement Opportunities

Bid Notice Abstract

Invitation to Bid (ITB)

Reference Number 10516456
Procuring Entity BAGUIO WATER DISTRICT - BAGUIO CITY
Title 4 pieces 4" Ø Pressure Reducing Valve with strainer complete with companion flanges and BNG
Area of Delivery Benguet

Solicitation Number: 01-182P-B	Status	Pending
Trade Agreement: Implementing Rules and Regulations		
Procurement Mode: Public Bidding	Associated Components	1
Classification: Goods		
Category: Water Service Connection Materials/Fittings	Bid Supplements	0
Approved Budget for the Contract: PHP 1,120,000.00		
Delivery Period:	Document Request List	0
Client Agency:		
Contact Person: Ma. Luisa C Tenedero Chairperson, Bids and Awards Committee BWD Compound, Utility Road Baguio City Benguet Philippines 2600 63-74-4424858 63-74-4424858 purchasing.bwd2014@gmail.com	Date Published	01/02/2024
	Last Updated / Time	31/01/2024 11:33 AM
	Closing Date / Time	27/02/2024 13:30 PM

Description

4 pieces 4" Ø Pressure-Reducing Valve with strainer complete with companion flanges and BNG
 Approved Budget Cost: ₱280,000.00/PC

Pressure-Reducing Valve Specifications:
 Pressure Rating: Up to 25 bar (375 psi)
 Minimum system pressure: 1.5 bar (22 psi)
 Standard downstream pressure setting range:
 For 2" to 10" diameter: 30-165 psi
 End Connection: Flanged ISO-P10, ISO-PN-16 and PN-25
 Materials:
 Valve Body: Ductile Iron A-536 65-45-12 and/or Cast Steel WBC A-216
 Inline control strainer SST316
 Pressure Gauge SST
 Pressure-Reducing Pilot Valve: SST316
 Indicator Rod SST316
 Coating: high-build fusion-bonded epoxy (FBE)
 Protection: External Polyester or Polyurethane

Maintenance, disassembly and reassembly of all the valve's component shall be made possible on site and in-line.

without the need to remove the valve from the line.

Simple field-adjustment pressure setting, requiring no special tools and with no system downtime

PRV Dimensions and Weight (approx.):

PRV Size / Diameter Length (mm) Weight (kg)

4" (100mm) 350 37

Note: The required length and weight should not be less than the specified measure.

This is a two (2) envelope system:

Envelope "A" to contain the following; among others:

- a) A refundable bid bond in the form of cash, Manager's, or Cashier's check equivalent to 2% or surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱ 50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of bids OR Bid Securing Declaration regardless of amount of bid;
- b) Terms of payment, delivery, warranty, bid validity and complete specifications;
- c) Brochure/s (Original);
- d) Proof of payment of a non-refundable fee of ₱5,000.00; otherwise, bids shall not be opened
- e) Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;
-For bidders who have foreign principal suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement.
-For locally produced / manufactured products, only a certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable;
- f) ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);
- g) International Certificate of Warranty.

Envelope "B" to contain the bid cost per unit.

Pre-bid conference:

9:30am via Zoom Application

Meeting ID: 452 718 8447

Password: 9Buvqr



Pre-bid Conference

Date	Time	Venue
15/02/2024	9:30:00 AM	Pre-bid conference: February 15, 2024 9:30 a.m. via Zoom Application Meeting ID: 452 718 8447 Password: 9Buvqr

Created by Ma. Luisa C Tenedero

Date Created 31/01/2024

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.

 	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600		Document No.	ADM-PUR-F003
	REQUEST FOR BIDS/QUOTATION (RQ)		Revision Date	October 29, 2019
			Revision No.	02

To: _____

 (Name of Supplier)

Contact Person: _____

Address: _____

Contact no.: _____

RQ No.: **01 – 182P-B**


PR / JO No.: **182P**




Date of RQ: **January 29, 2024**

Purpose of RQ:
 -Proposed installation of 4" Ø
 Transmission line and Distribution
 Lines of Zigzag Deepwell
 -proposed installation of 4" Ø x
 457LM PVC Mainline along Crystal
 Cave Road
 -Proposed installation of 4" Ø x
 517LM PVC Mainline and 3" Ø x
 516LM PVC Distribution Lines along
 Outlood Drive - Lucnab


NOTE: DATA REQUIRED MUST BE FILLED UP COMPLETELY. FAILURE TO INDICATE THE PRICE VALIDITY, TERMS, WARRANTY PERIOD AND DELIVERY PERIOD SHALL MEAN OUTRIGHT DISQUALIFICATION OF BIDS																										
	Qty.	Description	U-Price	Total																						
VALIDITY DATE: _____ day (30 days minimum) DELIVERY: _____ working days _____ calendar days _____ FOB warehouse WARRANTY _____ calendar days upon acceptance. TERMS:	4 pcs	4" Ø Pressure Reducing Valve with strainer complete with companion flanges and BNG Approved Budget Cost: ₱280,000.00 / pc Pressure Reducing Valve Specifications: <table border="1" style="width: 100%;"> <tr> <td>Pressure Rating:</td> <td>Up to 25 bar (375 psi) Minimum system pressure 1.5 bar (22 psi)</td> </tr> <tr> <td>Standard downstream pressure setting range:</td> <td>For 2" to 10" diameter: 30-165 psi</td> </tr> <tr> <td>End Connection:</td> <td>Flanged ISO- P10, ISO-PN-16 & PN-25</td> </tr> <tr> <td colspan="2">Materials:</td> </tr> <tr> <td>Valve Body:</td> <td>Ductile Iron A-536 65-45-12 and/or Cast Steel WBC A-216</td> </tr> <tr> <td>Inline control strainer</td> <td>SST316</td> </tr> <tr> <td>Pressure Gauge</td> <td>SST</td> </tr> <tr> <td>Pressure Reducing Pilot Valve</td> <td>SST316</td> </tr> <tr> <td>Indicator Rod</td> <td>SST316</td> </tr> <tr> <td>Coating</td> <td>High built fusion bonded epoxy (FBE)</td> </tr> <tr> <td>Protection</td> <td>External Polyester / Polyurethane</td> </tr> </table>	Pressure Rating:	Up to 25 bar (375 psi) Minimum system pressure 1.5 bar (22 psi)	Standard downstream pressure setting range:	For 2" to 10" diameter: 30-165 psi	End Connection:	Flanged ISO- P10, ISO-PN-16 & PN-25	Materials:		Valve Body:	Ductile Iron A-536 65-45-12 and/or Cast Steel WBC A-216	Inline control strainer	SST316	Pressure Gauge	SST	Pressure Reducing Pilot Valve	SST316	Indicator Rod	SST316	Coating	High built fusion bonded epoxy (FBE)	Protection	External Polyester / Polyurethane		
Pressure Rating:	Up to 25 bar (375 psi) Minimum system pressure 1.5 bar (22 psi)																									
Standard downstream pressure setting range:	For 2" to 10" diameter: 30-165 psi																									
End Connection:	Flanged ISO- P10, ISO-PN-16 & PN-25																									
Materials:																										
Valve Body:	Ductile Iron A-536 65-45-12 and/or Cast Steel WBC A-216																									
Inline control strainer	SST316																									
Pressure Gauge	SST																									
Pressure Reducing Pilot Valve	SST316																									
Indicator Rod	SST316																									
Coating	High built fusion bonded epoxy (FBE)																									
Protection	External Polyester / Polyurethane																									







February 27, 2024

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600		Document No.	ADM-PUR-F003
	REQUEST FOR BIDS/QUOTATION (RQ)		Revision Date	October 29, 2019
			Revision No.	02

		Maintenance, disassembly and reassembly of all the valve's component shall be made possible on site and in-line, without the need to remove the valve from the line.								
		Simple field-adjustment pressure setting, requiring no special tools and with no system downtime								
		PRV Dimensions and Weight (Approx.):								
		<table><tr><td>PRV Size / Diameter</td><td>Length (mm)</td><td>Weight (kg)</td></tr><tr><td>4" (100mm)</td><td>350</td><td>37</td></tr></table>	PRV Size / Diameter	Length (mm)	Weight (kg)	4" (100mm)	350	37		
PRV Size / Diameter	Length (mm)	Weight (kg)								
4" (100mm)	350	37								
		Note: Required length and weight should not be less than the specified measure.								
		<div>X X X X X</div>								
		This is a two (2) envelope system:								
		Envelope "A" to contain the following; among others:								
		<div><div>a) A refundable bid bond in the form of cash, Manager's, or Cashier's check equivalent to 2% or surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱ 50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of bids OR Bid Securing Declaration regardless of amount of bid;</div><div>b) Terms of payment, delivery, warranty, bid validity and complete specifications;</div><div>c) Brochure/s (Original);</div><div>d) Proof of payment of a non-refundable fee of ₱5,000.00; otherwise, bids shall not be opened</div><div>e) Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;</div></div>								
		-For bidders who have foreign principal suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement.								
		-For locally produced / manufactured products, only a certificate of Authorized Distributorship / Dealership w/o								



February 27, 2024

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600		Document No.	ADM-PUR-F003
	REQUEST FOR BIDS/QUOTATION (RQ)		Revision Date	October 29, 2019
			Revision No.	02
<p>red ribbon is required if applicable;</p> <p>f) ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);</p> <p>g) International Certificate of Warranty.</p> <p>Envelope "B" to contain the bid cost per unit.</p> <p>Pre-bid conference: February 15, 2024 9:30am via Zoom Application Meeting ID: 452 718 8447 Password: 9Buvqr</p>				

By: Supplier or Authorized Representative: _____ (sign over printed name)

Deadline of submission of bids: February 27, 2024 Opening of bids: 1:30 pm

Prepared by: MGLamangan Noted by: ATTY. MA. LUISA C. TENEDERO ENGR. REYNALDO C. JAYCO
PURCHASING BAC IN-HOUSE BAC-TECHNICAL

**BWD RESERVES THE RIGHT TO REJECT BIDS &/OR DECLARE A FAILURE OF BIDDING
PURSUANT TO THE PERTINENT PROVISIONS OF RA 9184**

**BWD DOES NOT ENGAGE IN SOLICITATION OF FUNDS FROM ANY INDIVIDUALS OR ENTITIES, AND WE STRONGLY ADVISE
AGAINST RESPONDING TO ANY UNAUTHORIZED REQUESTS CLAIMING ASSOCIATION WITH OUR ORGANIZATION.**

Telefax No. (074) 442-4858 (Purchasing) / 444-7246