



BAGUIO WATER DISTRICT
"Serving Mankind is Serving God"
003 Purok BWD, Brgy., Marcoville, Baguio City
Tel. No. 442-4858 Fax No. 442-4858/444-7245

Document No.:	ADM-PUR-F006
Effectivity Date:	February 15, 2020
Revision No.:	00

No. 035739

PURCHASE ORDER

Supplier : KEYLARGO INDUSTRIAL SALES	P.O. No. : 35739
Tel No./ Fax No. : 02-284-2856 / 961-52-60 local 218	Date : January 31, 2024
Address / TIN : 1471 Quezon Ave. West Triangle Q.C.	PR No./Abstract No. : 01-203P

Gentlemen/ Madam,

Please furnish this Office the following articles subject to the terms and conditions contained herein.

Place of Delivery : <input type="checkbox"/> Pick up <input checked="" type="checkbox"/> FOB BWD Warehouse <input type="checkbox"/> Deliver at site	P.O. Valid Until : 30 working days Warranty : <input type="checkbox"/> Six months <input checked="" type="checkbox"/> One year <input type="checkbox"/> Others (Pls. Specify)
Date of Delivery : 20-25 weeks <input type="checkbox"/> Working days <input type="checkbox"/> Calendar Days upon receipt of PO	<input checked="" type="checkbox"/> 1% Retention Required <input type="checkbox"/> Performance Bond Required (5% if in check/50% if GSIS surety bond) <input checked="" type="checkbox"/> Subject to testing / inspection prior to payment
Delivery Term : <input type="checkbox"/> full <input type="checkbox"/> partial delivery allowed	Payment Term : <input type="checkbox"/> COD <input type="checkbox"/> 30 Days <input checked="" type="checkbox"/> Others (Pls. Specify) 30 days

Quantity	Unit	Description/Specifications	Unit Cost	Amount
4	units	"Danfoss" (Denmark) Soft Starter Motor Controller Model: MCD60042BT7S1X20CV2 Capacity of Motor to be controlled by the Soft Starter Motor rating: 20HP ; Voltage Rating: 460V nominal ; Supply Frequency: 60Hz ; Number of Phase: 3 Phase ; Speed (Nom): 3600 RPM	120,000.00 ₱	480,000.00
2	units	"Danfoss" (Denmark) Soft Starter Motor Controller Model: MCD60063BT7S1X20CV2 Capacity of Motor to be controlled by the Soft Starter Motor rating: 30HP ; Voltage Rating: 460V nominal ; Supply Frequency: 60Hz ; Number of Phase: 3 Phase ; Speed (Nom): 3600 RPM	135,000.00	270,000.00
4	units	"Danfoss" (Denmark) Soft Starter Motor Controller Model: MCD60069BT7S1X20CV2 Capacity of Motor to be controlled by the Soft Starter Motor rating: 40HP ; Voltage Rating: 460V nominal ; Supply Frequency: 60Hz ; Number of Phase: 3 Phase ; Speed (Nom): 3600 RPM	150,000.00	600,000.00
2	units	"Danfoss" (Denmark) Soft Starter Motor Controller Model: MCD60108BT7S1X20CV2 Capacity of Motor to be controlled by the Soft Starter Motor rating: 50HP ; Voltage Rating: 460V nominal ; Supply Frequency: 60Hz ; Number of Phase: 3 Phase ; Speed (Nom): 3600 RPM	170,000.00	340,000.00
x x x x (Please refer to the attached sheet for complete detailed specifications)				₱ 1,690,000.00

Usage / Requisitioner




For upgrade of controls submersible pumps c/o Engr. JBPamaylaon



EMAILED


2/10/24

Prepared by: MARCOS G. LAMANGAN Purchasing Supervisor	Checked by: ATTY. CHANEL DOLOR D. DE GUZMAN Admin Division Manager	Audited by: LUZVIMIN G. RAMOS Internal Auditor	Recommending Approval: ATTY. MA. LUISA C. TENEDERO AGM-Adm./Com./Fin.	Approved By: ENGR. SALVADOR M. ROYCE General Manager
Conforme:				
Signature over Printed Name of Supplier		Date		
Funds Available: JELYN S. PENALES Finance Manager		Acct. : Operating / Maintenance Expense <input type="checkbox"/> CAPEX <input type="checkbox"/> Other Payables <input checked="" type="checkbox"/>		

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600	Document No. : ADM-PUR-F006
	PURCHASE ORDER (P.O.)	Revision Date : February 15, 2020
		Revision No. : 00




Supplier/Contractor : KEYLARGO INDUSTRIAL SALES	Purchase Order No. : 35739
Contact Number : 02-248-2856/961-52-60 local 218	Date : January 31, 2023
Address / TIN : 1471 Quezon Ave. West Triangle Quezon City	PR No./Abstract No. : 01-203P

Qty	Unit	Description	Unit Cost	Amount
4	units	"Danfoss" (Denmark) Soft Starter Motor Controller	120,000.00	480,000.00
		Model: MCD60042BT7S1X20CV2		
		Capacity of Motor to be controlled by the Soft Starter		
		Motor rating: 20HP		
		Voltage Rating: 460V nominal		
		Supply Frequency: 60Hz		
		Number of Phase: 3 Phase		
		Speed (Nom): 3600 RPM		
2	units	"Danfoss" (Denmark) Soft Starter Motor Controller	135,000.00	270,000.00
		Model: MCD60063BT7S1X20CV2		
		Capacity of Motor to be controlled by the Soft Starter		
		Motor rating: 30HP		
		Voltage Rating: 460V nominal		
		Supply Frequency: 60Hz		
		Number of Phase: 3 Phase		
		Speed (Nom): 3600 RPM		
4	units	"Danfoss" (Denmark) Soft Starter Motor Controller	150,000.00	600,000.00
		Model: MCD60069BT7S1X20CV2		
		Capacity of Motor to be controlled by the Soft Starter		
		Motor rating: 40HP		
		Voltage Rating: 460V nominal		
		Supply Frequency: 60Hz		
		Number of Phase: 3 Phase		
		Speed (Nom): 3600 RPM		
2	units	"Danfoss" (Denmark) Soft Starter Motor Controller	170,000.00	340,000.00
		Model: MCD60108BT7S1X20CV2		
		Capacity of Motor to be controlled by the Soft Starter		
		Motor rating: 60HP		
		Voltage Rating: 460V nominal		
		Supply Frequency: 60Hz		
		Number of Phase: 3 Phase		
		Speed (Nom): 3600 RPM		
		Soft Starter Specifications:		
		1. Main Voltage		
		L1, L2, L3	200VAC – 300VAC (+/- 10%)	



EMAILED

2/6/24

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600		Document No.	ADM-PUR-F006
	PURCHASE ORDER (P.O.)		Revision Date	February 15, 2020
			Revision No.	00

Qty	Unit	Description	Unit Cost	Amount
		2. Control Voltage		
		(A4, A6) 220-240VAC (+10% / -15%)		
		Main Frequency 60Hz (+/- 10%)		
		Rated insulation Voltage to earth 600VAC		
		Rated impulse withstand voltage 4kV		
		3. Short Circuit Capability		
		Coordination Semi-conductor fuses		
		Prospective current 65kA		
		4. Outputs		
		Relay outputs 10A @ 250VAC resistive		
		Programmable outputs 1 (NC), 1 (NO), 1 (CO)		
		Analogue outputs 4-20mA		
		Maximum load 600Ω (12VDC @ 20mA accuracy +/-5%)		
		24VDC output, maximum load 200mA (accuracy +/- 10%)		
		5. Environmental		
		Protection IP20 & NEMA, UL indoor type 1		
		Operating temperature -10°C to 60°C		
		Storage temperature -25°C to 60°C		
		6. Heat Dissipation		
		During start 4.5 watts per ampere		
		Note: Soft Starter should be equipped with SCADA ready device		
		- Bidder to submit certificate of sole distributorship		
		- Supplier to be present during testing / commissioning		

Total: ₱1,690,000.00

Usage: For upgrade of controls of submersible pumps c/o Engr. JBPamaylaon


Prepared by:


Checked by:


Audited by:


Recommending
Approval:


Approved by:


M. G. Lamangan
SMPO


Atty. C.D. De Guzman
Administrative Div. Manager


L. G. Ramos
Internal Auditor


Atty. M.L.C. Tenedero
AGM Adm./Com./Fin./ICT


Engr. Salvador M. Royeca
General Manager



EMAILED

2/6/24



BAGUIO WATER DISTRICT
Bids and Awards Committee
(In-house)

RESOLUTION

Document Code: BAC_IH

Document No. BAC_IH_F002

Effective Date: 16 March 2020

Revision No. 00

BIDS AND AWARDS COMMITTEE
RESOLUTION NO. 008-2024

Request for Quotation (RQ) No. 11-203P: Soft Starter Motor Controller

WHEREAS, the Baguio Water District-Bids and Awards Committee (BWD-BAC), in accordance with the provisions of Republic Act (RA) No. 9184, conducted the bidding for the procurement of the following, all with required specifications under RQ No. 11-203P, dated 18 November 2023, under a two-envelope system of bidding but not to be awarded on a one lot basis and with approved budget unit costs of:

Quantity	Description	ABC (per unit)
4 units	20HP Soft Starter Motor Controller	Php120,000.00
2 units	30HP Soft Starter Motor Controller	Php135,000.00
4 units	40HP Soft Starter Motor Controller	Php150,000.00
2 units	60HP Soft Starter Motor Controller	Php170,000.00

WHEREAS, only **KEYLARGO INDUSTRIAL SALES** submitted its bids and during the opening of the technical bids on 18 December 2023, it was determined that the lone bidder submitted complete documentary requirements;

WHEREAS, upon evaluation by the Technical Working Group of the offers of the lone bidder, it was determined that said bidder submitted complying offers thus, its financial bids were opened and the bids as read and calculated are as follows:

DESCRIPTION	BID PRICE (per unit)	% VARIANCE FROM ABC	ABC (per unit)
KEYLARGO INDUSTRIAL SALES			
20HP Soft Starter Motor Controller	Php120,000.00	-0-	Php120,000.00
30HP Soft Starter Motor Controller	Php135,000.00	-0-	Php135,000.00
40HP Soft Starter Motor Controller	Php150,000.00	-0-	Php150,000.00
60HP Soft Starter Motor Controller	Php170,000.00	-0-	Php170,000.00

WHEREAS, upon post-qualification, careful examination, validation, and verification of all the documents submitted by and of the financial bids of the complying bidder, it has been determined that **KEYLARGO INDUSTRIAL SALES** submitted complete documents and its financial bids are determined to be the lone calculated responsive bid;

NOW THEREFORE, on motion duly seconded, be it

RESOLVED, as it is hereby resolved, to recommend to the Head of the Procuring Entity (HoPE) awarding the procurement of the above-mentioned soft starter motor controllers to **KEYLARGO INDUSTRIAL SALES** with the offered brands, specifications, and bid prices for being the lone calculated responsive bidder.

UNANIMOUSLY APPROVED (12 January 2024)

Engr. Noriel C. Calpito
Vice-Chairperson

Rodrigo O. De Venedia, Jr
Member

Engr. Shayne Margie S. Abellera
Member

Romeo S. Adriano
Member

Engr. Dominic T. Agusdan
Member

Atty. Frances Louise E. Genar
Member

Atty. Ma. Luisa C. Tenedero
Chairperson

Attested by:

Apple Jane P. Aviles
Secretariat

Sharlene M. Durante
Secretariat

Approved by:

Engr. Salvador M. Royeca
General Manager