

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600	Document No.	ADM-PUR-F003
	REQUEST FOR BIDS/QUOTATION (RQ)	Revision Date	October 29, 2019
		Revision No.	02

To: _____
(Name of Supplier)

Contact Person: _____

Address: _____

Contact no.: _____

RQ No.: **01 – 023P-B**

PR / JO No.: **023P**

Date of RQ: **January 29, 2024**

Purpose of RQ:
For various BWD Projects

NOTE: DATA REQUIRED MUST BE FILLED UP COMPLETELY. FAILURE TO INDICATE THE PRICE VALIDITY, TERMS, WARRANTY PERIOD AND DELIVERY PERIOD SHALL MEAN OUTRIGHT DISQUALIFICATION OF BIDS													
	Qty.	Description	U-Price	Total									
VALIDITY DATE: _____ day (30 days minimum)	1 pc	4" Ø Gate Valve, flanged type with combination flanges and sealing ring and bolts & nuts (please see complete specifications below) Approved Budget Cost: ₱18,303.30 / pc											
DELIVERY: _____ working days _____ calendar days _____ FOB warehouse	4 pcs	2" Ø Gate Valve, flanged type with combination flanges and sealing ring and bolts & nuts (please see complete specifications below) Approved Budget Cost: ₱11,600.00 / pc											
WARRANTY _____ calendar days upon acceptance.	1 pc	6" Ø Gate Valve, flanged type with companion steel flanges and BNG (please see complete specifications below) Approved Budget Cost: ₱42,560.00 / pc											
TERMS:		GATE VALVE FLANGED TYPE SPECIFICATION: Design Code: Hydraulic test to BS 5163 (DIN3230 / DIN3352) or JIS B2043, DIN 3352, AWWA C509, BS5163 Maximum Pressure: PN16 or 16 bar Temperature Range: -20 to 160 degrees centigrade Face to Face: BS 5163 or JIS B2002, DIN 3202-F5, DIN 3202-F4, ANSI B16.10, BS 5163 End Flange: EN1092-2 (ISO 7005-2) or JIS B2212 10K, DIN 2533 PN 10/16, ANSI 150#, BS4504 PN 10/16 Tightness Test: Operating Torque Test or JIS B2003, DIN 3230, AWWA C509, BS 6755 Materials: Body: Ductile Iron, GGG-50 to DIN 1693 (BS 2789 grade 500-7) or Ductile Iron Wedge: Ductile Iron (DI) + NBR or Ductile Iron, GGG-50, core fully encapsulated with EPDM rubber with integral wedge nut of dezincification resistant brass, CZ 132 to BS 2874 Wedge Nut: Brass or Dezincification Resistant Brass Stem: Stainless Steel, DIN X 20 Cr 13 or Stainless Steel / Brass Bonnet Gasket: EPDM Rubber or EPDM / NBR Bonnet: Ductile Iron (DI) or Stainless Steel A2, sealed with hot melt O-Ring: NBR or EPDM / NBR Stem Collar: Brass Gland Flange: Ductile Iron or Ductile Iron GJS-500-7 (GGG-50) Dustproof Ring: NBR or EPDM / NBR Handwheel: Ductile Iron (DI) Hex Nut: Cast Iron Overall Dimensions: <table><tr><td>Size / DN</td><td>Length (L) mm</td><td>Height (H) mm</td><td>Width or D mm</td><td>Weight kgs</td></tr><tr><td>DN50 (2")</td><td>178</td><td>300-241</td><td>160-165</td><td>13-14</td></tr></table>	Size / DN	Length (L) mm	Height (H) mm	Width or D mm	Weight kgs	DN50 (2")	178	300-241	160-165	13-14	
Size / DN	Length (L) mm	Height (H) mm	Width or D mm	Weight kgs									
DN50 (2")	178	300-241	160-165	13-14									

		<table><tr><td>DN100 (4")</td><td>229</td><td>334-430</td><td>200-220</td><td>26-28</td></tr><tr><td>DN150 (6")</td><td>267</td><td>448-565</td><td>260-285</td><td>51-52</td></tr></table> <div>X X X X X</div> <p>Note: Not to be awarded on a one (1) lot basis.</p> <p>This is a two (2) envelope system: Envelope "A" to contain the following; among others:</p> <div><div>a) A refundable bid bond in the form of cash, Manager's or Cashier's check equivalent to 2% or surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of bids OR Bid Securing Declaration regardless of amount of bid;</div><div>b) Terms of payment, delivery, warranty, bid validity and complete specifications;</div><div>c) Brochure/s (Original);</div><div>d) Proof of payment of a non-refundable fee of ₱500.00; otherwise, bids shall not be opened</div><div>e) Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;</div></div> <div><div>-For bidders who have foreign principal suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement.</div><div>-For locally produced / manufactured products, only a certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable;</div></div> <div><div>f) ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);</div><div>g) International Certificate of Warranty.</div></div> <p>Envelope "B" to contain the bid cost per unit.</p>	DN100 (4")	229	334-430	200-220	26-28	DN150 (6")	267	448-565	260-285	51-52		
DN100 (4")	229	334-430	200-220	26-28										
DN150 (6")	267	448-565	260-285	51-52										

By: Supplier or Authorized Representative: _____ (sign over printed name)

Deadline of submission of bids: February 28, 2024 Opening of bids: 1:30 pm

For: 
Prepared by: MGLamangan
PURCHASING


Noted by: ATTY. MA. LUISA C. TENEDERO
BAC IN-HOUSE


ENGR. REYNALDO C. JAYCO
BAC-TECHNICAL

**BWD RESERVES THE RIGHT TO REJECT BIDS &/OR DECLARE A FAILURE OF BIDDING
PURSUANT TO THE PERTINENT PROVISIONS OF RA 9184**

**BWD DOES NOT ENGAGE IN SOLICITATION OF FUNDS FROM ANY INDIVIDUALS OR ENTITIES, AND WE STRONGLY ADVISE
AGAINST RESPONDING TO ANY UNAUTHORIZED REQUESTS CLAIMING ASSOCIATION WITH OUR ORGANIZATION.**

Telefax No. (074) 442-4858 (Purchasing) / 444-7246