



**No 035840**

**PURCHASE ORDER**

Supplier : <b>AVK PHILIPPINES, INC.</b>	P.O. No. : <b>35840</b>
Tel No./ Fax No. : <b>(02) 376-6400 to 01</b>	Date : <b>March 7, 2024</b>
Address / TIN : <b>70 West Ave. Brgy. West Triangle Q.C</b>	PR No./Abstract No. : <b>02-012P-B</b>

Gentlemen/ Madam,

Please furnish this Office the following articles subject to the terms and conditions contained herein.

Place of Delivery : <input type="checkbox"/> Pick up <input checked="" type="checkbox"/> <b>FOB BWD Warehouse</b> <input type="checkbox"/> Deliver at site	P.O. Valid Until : <b>30 DAYS (calendar)</b> Warranty : <input type="checkbox"/> Six months <input checked="" type="checkbox"/> <b>One year</b> <input type="checkbox"/> Others(Pls. Specify)
Date of Delivery : <b>30</b> Working days <input type="checkbox"/> Calendar Days upon receipt of PO	<input checked="" type="checkbox"/> <b>1% Retention Required</b> <input type="checkbox"/> Performance Bond Required (5% if in check/50% if GSIS surety bond)
Delivery Term : <input type="checkbox"/> full <input type="checkbox"/> partial delivery allowed	<input type="checkbox"/> Subject to testing / inspection prior to payment Payment Term : <input type="checkbox"/> COD <input checked="" type="checkbox"/> <b>30 Days</b> <input type="checkbox"/> Others(Pls. Specify)

Quantity	Unit	Description/Specifications	Unit Cost	Amount
2	sets	"AVK" 6"Ø Gate Valve, flanged type with companion steel flanges and BNG, PN 16  X-X-X-X-X-X-X-X-X-X-X-X (Please see attached sheet for complete detailed specifications)	32,666.51 P	65,333.02
Usage / Requisitioner <b>Proposed installation of 4"Ø x 66LM PVC Transmission Line along Montinola Subd., Kisad Road, Baguio City c/o JJ Balangcod</b>				



**EMAILED**




**3/14/24**

Prepared by: <b>MARCOS G. LAMANGAN</b> Purchasing Supervisor	Checked by: <b>ATTY. CHANEL DOLORO DE GUZMAN</b> Admin Division Manager	Audited by: <b>LUZVIMIN G. RAMOS</b> Internal Auditor	Recommending Approval: <b>ATTY. MA. KRISA TENERERO</b> AGM-Adm./Com./Fin.	Approved By: <b>ENGR. SALVADOR M. ROYCECA</b> General Manager
---	--	--	--	--

Conforme:	Signature over Printed Name of Supplier	Date
-----------	---	------

Funds Available: <b>JELYN D. PENALES</b> Finance Manager	Acct. : Operating / Maintenance Expense <input type="checkbox"/> CAPEX <input checked="" type="checkbox"/> Other Payables <input type="checkbox"/>
---	---





BAGUIO WATER DISTRICT

BWD Compound, Utility Road, Baguio City 2600

Document No.

ADM-PUR-F006

PURCHASE ORDER (P.O)

Revision Date

February 15, 2020

Revision No.

00

Supplier/Contractor : AVK PHILIPPINES, INC. -

Purchase Order No. : 35840 ✓

Contact Number : 02-376-6400 to 01

Date : March 7, 2024

Address / TIN : 70 West Ave. Brgy. West Triangle, Q.C

PR No./Abstract No. : 02-012P-B ✓

Qty	Unit	Description	Unit Cost	Amount										
2	sets	"AVK" 6" Ø Gate Valve, flanged type with companion steel flanges and BNG, PN 16 ✓	32,666.51	65,333.02										
		<div><b>Design Code:</b> Hydraulic test to BS 5163 (DIN3230 / DIN3352) ✓ Maximum Pressure: PN16 ✓ Temperature Range: -20 to 160 degrees centigrade ✓ Face to Face: BS 5163 ✓ End Flange: EN1092-2 (ISO 7005-2) ✓ Tightness Test: Operating Torque Test ✓ <b>Materials:</b> Body: Ductile Iron, GGG-50 to DIN 1693 (BS 2789 grade 500-7) ✓ Wedge: Ductile Iron, GGG-50, core fully encapsulated with EPDM rubber with integral wedge nut of dezincification resistant brass, CZ 132 to BS 2874 ✓ Wedge Nut: Dezincification Resistant Brass ✓ Stem: Stainless Steel, DIN X 20 Cr 13 or Stainless Steel / Brass ✓ Bonnet Gasket: EPDM Rubber ✓ Bonnet: Stainless Steel A2, sealed with hot melt ✓ O-Ring: NBR or EPDM / NBR ✓ Stem Collar: Brass ✓ Gland Flange: Ductile Iron GJS-500-7 (GGG-50) ✓ Dustproof Ring: NBR or EPDM / NBR ✓ Hex Nut: Cast Iron ✓  Overall Dimensions:<table><tr><th>Size / DN</th><th>Length (L) mm</th><th>Height (H) mm</th><th>Width (D) mm</th><th>Weight (kgs.)</th></tr><tr><td>6"/DN100 150</td><td>267</td><td>448</td><td>285</td><td>51</td></tr></table></div>	Size / DN	Length (L) mm	Height (H) mm	Width (D) mm	Weight (kgs.)	6"/DN100 150	267	448	285	51		
Size / DN	Length (L) mm	Height (H) mm	Width (D) mm	Weight (kgs.)										
6"/DN100 150	267	448	285	51										

Total: ₱65,333.02

Usage: Proposed installation of 4"Ø x 66LM PVC Transmission Line along Montinola Subd., Kisad Road, Baguio City c/o JJ Balangcod

Prepared by: M. G. Lamangan  
SMPO

Checked by: Atty. C.D. De Guzman  
Administrative Div. Manager

Audited by: L. G. Ramos  
Internal Auditor

Recommending Approval: Atty. M.L.C. Tenedero  
AGM  
Adm./Com./Fin./ICT

Approved by: Engr. Salvador M. Royeca  
General Manager





**BAGUIO WATER DISTRICT**  
**Bids and Awards Committee**  
**(In-house)**

**RESOLUTION**

Document Code: BAC\_IH

Document No. BAC\_IH\_F002

Effective Date: 16 March 2020

Revision No. 00

**BIDS' AND AWARDS COMMITTEE**  
**RESOLUTION NO. 039-2024**

Request for Quotation (RQ) No. 01-012P-B: 6" Ø Gate Valves

**WHEREAS**, the Baguio Water District-Bids and Awards Committee (BWD-BAC), in accordance with the provisions of Republic Act (RA) No. 9184, conducted the bidding for the procurement of two (2) pieces of 6" Ø gate valves, with required specifications under RQ No. 01-012P-B, dated 15 January 2024, under a two-envelope system of bidding;

**WHEREAS**, the approved budget cost is Php42,560.00/piece;

**WHEREAS**, AVK PHILIPPINES, INC. and FANM ENTERPRISES, INC. submitted their bids and during the opening of the technical bids on 31 January 2024, it was determined that both bidders submitted complete documentary requirements thus, their bids were rated "*passed*";

**WHEREAS**, the technical proposals of the bidders were endorsed to the Technical Working Group (TWG) for evaluation, and on 14 February 2024 their bids were rated by the TWG as "*complying*";

**WHEREAS**, on 20 February 2024, the financial bids of the complying bidders were opened and the bids as read and calculated are as follows:

NAME OF BIDDER	BID PRICE (per piece)	% VARIANCE FROM ABC	ABC (per piece)
AVK PHILIPPINES, INC.	Php32,666.51	23.24%	Php42,560.00
FANM ENTERPRISES, INC.	Php42,560.00	0%	Php42,560.00

**WHEREAS**, upon post-qualification, careful examination, validation, and verification of all the documents submitted by and of the financial bids of the complying bidders, it has been determined that AVK PHILIPPINES, INC. submitted complete documents and its financial bid is determined to be the lowest calculated responsive bid;

**NOW THEREFORE, on motion duly seconded, be it**

**RESOLVED**, as it is hereby resolved, to recommend to the Head of the Procuring Entity (HoPE) awarding the procurement of 2 pieces of 6" Ø gate valves to AVK PHILIPPINES, INC. with the offered brands, specifications, and price for being the lowest calculated responsive bidder.

**UNANIMOUSLY APPROVED (21 February 2024)**

Engr. Noriel C. Calpito  
Vice-Chairperson

Rodrigo O. De Venecia, Jr.  
Member

Engr. Shayne Margie S. Abellera  
Member

Romeo S. Adriano  
Member

Engr. Dominic T. Agusdan  
Member

Atty. Francess Louise E. Gener  
Member

Atty. Ma. Luisa C. Tenedero  
Chairperson

Attested by:

Apple Jane P. Aviles  
Secretariat

Sharlene M. Durante  
Secretariat

Approved by:

Engr. Salvador M. Royeca  
General Manager