



BAGUIO WATER DISTRICT
"Serving Mankind is Serving God"
003 Purok BWD, Brgy., Marcoville, Baguio City
Tel. No. 442-4858 Fax No. 442-4858/444-7245

Document No.:	ADM-PUR-F006
Effectivity Date:	February 15, 2020
Revision No.:	00

No 035841

PURCHASE ORDER

Supplier : AVK PHILIPPINES, INC.	P.O. No. : 35841
Tel No./ Fax No. : (02) 376-6400 to 01	Date : March 7, 2024
Address / TIN : 70 West Ave. Brgy. West Triangle Q.C	PR No./Abstract No. : 02-003P-B

Gentlemen/ Madam,

Please furnish this Office the following articles subject to the terms and conditions contained herein.

Place of Delivery : <input type="checkbox"/> Pick up <input checked="" type="checkbox"/> FOB BWD Warehouse <input type="checkbox"/> Deliver at site	P.O. Valid Until : 30/07/25 (calendar) Warranty : <input type="checkbox"/> Six months <input checked="" type="checkbox"/> One year <input type="checkbox"/> Others (Pls. Specify)
Date of Delivery : 30 Working days <input type="checkbox"/> Calendar Days upon receipt of PO	<input checked="" type="checkbox"/> 1% Retention Required <input type="checkbox"/> Performance Bond Required (5% if in check/50% if GSIS surety bond)
Delivery Term : <input type="checkbox"/> full <input type="checkbox"/> partial delivery allowed	<input checked="" type="checkbox"/> Subject to testing / inspection prior to payment Payment Term : <input type="checkbox"/> COD <input checked="" type="checkbox"/> 30 Days <input type="checkbox"/> Others (Pls. Specify)

Quantity	Unit	Description/Specifications	Unit Cost	Amount
1.	pc	"AVK" 4"Ø Gate Valve, flanged type with companion steel flanges and BNG "AVK"	18,046.80 ₱	18,046.80
1	pc	"AVK" 4"Ø Gate Valve, flanged type with combination flanges and sealing ring and bolts & nuts	16,187.90	16,187.90
X X X X X				₱ 34,234.70

(Please refer to the attached sheet for complete detailed specifications)



EMAILED

3/14/24

Usage / Requisitioner **Proposed upsizing of the 3"Ø Mainline and 2"Ø Distribution line along Lower Pinget, Baguio City**
(installation of 4"Ø x 470m PVC Mainline and 3"Ø x 240m PVC Distribution Line) c/o JJ Balangcod

Prepared by:

Checked by:

Audited by:

Recommending Approval:

Approved By:

MARCOS G. LAMANGAN
Purchasing Supervisor

ATTY. CHANELL DOLOR D. DE GUZMAN
Admin Division Manager

LUZVIMIN G. RAMOS
Internal Auditor

ATTY. M. LUISA G. TENEDERO
AGM-Adm./Com./Fin.

ENGR. SALVADOR M. ROYECAL
General Manager

Conforme:

Signature over Printed Name of Supplier




Date

Funds Available:

JEJYN D. PENALES
Finance Manager

Acct. :

Operating / Maintenance Expense ☐
CAPEX ☒
Other Payables ☐






  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600	Document No.	ADM-PUR-F006
	PURCHASE ORDER (P.O)	Revision Date	February 15, 2020
		Revision No.	00

Supplier/Contractor	: AVK PHILIPPINES, INC.	Purchase Order No.	: 35841
Contact Number	: 02-376-6400 to 01	Date	: March 7, 2024
Address / TIN	: 70 West Ave. Brgy. West Triangle, Q.C	PR No./Abstract No.	: 02-003P-B

Qty	Unit	Description	Unit Cost	Amount										
1	Pc	4" Ø Gate Valve, flanged type with companion steel flanges and BNG, "AVK". (please see complete specifications below)	18,046.80	18,046.80										
1	Pc	4" Ø Gate Valve, flanged type with combination flanges and sealing ring and bolts and nuts "AVK" (please see complete specifications below)	16,187.90	16,187.90										
		GATE VALVE FLANGED TYPE SPECIFICATIONS: Design Code: Hydraulic test to BS 5163 (DIN3230 / DIN3352) Maximum Pressure: PN16 Temperature Range: -20 to 160 degrees centigrade Face to Face: BS 5163 End Flange: EN1092-2 (ISO 7005-2) Tightness Test: Operating Torque Test Materials: Body: Ductile Iron, GGG-50 to DIN 1693 (BS 2789 grade 500-7) Wedge: Ductile Iron, GGG-50, core fully encapsulated with EPDM rubber with integral wedge nut of dezincification resistant brass, CZ 132 to BS 2874 Wedge Nut: Dezincification Resistant Brass Stem: Stainless Steel, DIN X 20 Cr 13 or Stainless Steel / Brass Bonnet Gasket: EPDM Rubber Bonnet: Stainless Steel A2, sealed with hot melt O-Ring: NBR or EPDM / NBR Stem Collar: Brass Gland Flange: Ductile Iron GJS-500-7 (GGG-50) Dustproof Ring: NBR or EPDM / NBR Hex Nut: Cast Iron Overall Dimensions: <table><tr><th>Size / DN</th><th>Length (L) mm</th><th>Height (H) mm</th><th>Width (D) mm</th><th>Weight (kgs.)</th></tr><tr><td>4"/DN100</td><td>229</td><td>334</td><td>220</td><td>26</td></tr></table>	Size / DN	Length (L) mm	Height (H) mm	Width (D) mm	Weight (kgs.)	4"/DN100	229	334	220	26		
Size / DN	Length (L) mm	Height (H) mm	Width (D) mm	Weight (kgs.)										
4"/DN100	229	334	220	26										

Total: **₱34,234.70**

Usage: Proposed upsizing of the 3"Ø Mainline and 2"Ø Distribution line along Lower Pinget, Baguio City (installation of 4"Ø x 470m PVC Mainline and 3"Ø x 240m PVC Distribution Line) c/o JJ Balangcod

Prepared by:	Checked by:	Audited by:	Recommending Approval:	Approved by:
 M. G. Lamangan SMPO	 Atty. C.D. De Guzman Administrative Div. Manager	 L. G. Ramos Internal Auditor	 Atty. M.L.C. Tenedero AGM Adm./Com./Fin./ICT	 Engr. Salvador M. Royeca General Manager

BIDS AND AWARDS COMMITTEE
RESOLUTION NO. 040-2024
Request for Quotation (RQ) No. 01-003P-B: 4" Ø Gate Valves

WHEREAS, the Baguio Water District-Bids and Awards Committee (BWD-BAC), in accordance with the provisions of Republic Act (RA) No. 9184, conducted the bidding for the procurement of the following, all with required specifications under RQ No. 01-003P-B, dated 08 January 2024, under a two-envelope system of bidding;

Quantity	Description	ABC (per piece)
1 piece	4" Ø Gate valve, flange type with companion steel flanges and BNG	Php22,075.00
1 piece	4" Ø Gate valve, flange type with combination flanges and sealing ring and bolts & nuts	Php18,303.30

WHEREAS, AVK PHILIPPINES, INC. and FANM ENTERPRISES, INC. submitted their bids and during the opening of the technical bids on 31 January 2024, it was determined that both bidders submitted complete documentary requirements thus, their bids were rated "passed";

WHEREAS, the technical proposals of the bidders were endorsed to the Technical Working Group (TWG) for evaluation, and on 14 February 2024 their bids were rated by the TWG as "complying";

WHEREAS, on 20 February 2024, the financial bids of the complying bidders were opened and the bids as read and calculated are as follows:

Description	BID PRICE (per piece)	% VARIANCE FROM ABC	ABC (per piece)
AVK PHILIPPINES, INC.			
4" Ø Gate valve, flange type with companion steel flanges and BNG	Php18,046.80	18.24%	Php22,075.00
4" Ø Gate valve, flange type with combination flanges and sealing ring and bolts & nuts	Php16,187.90	11.55%	Php18,303.30
FANM ENTERPRISES, INC.			
4" Ø Gate valve, flange type with companion steel flanges and BNG	Php22,075.00	-0-	Php22,075.00
4" Ø Gate valve, flange type with combination flanges and sealing ring and bolts & nuts	Php18,303.30	-0-	Php18,303.30

WHEREAS, upon post-qualification, careful examination, validation, and verification of all the documents submitted by and of the financial bids of the complying bidders, it has been determined that AVK PHILIPPINES, INC. submitted complete documents and its financial bids are determined to be the lowest calculated responsive bids;

NOW THEREFORE, on motion duly seconded, be it

RESOLVED, as it is hereby resolved, to recommend to the Head of the Procuring Entity (HoPE) awarding the procurement of the above-mentioned gate valves to AVK PHILIPPINES, INC. with the offered brands, specifications, and bid prices for being the lowest calculated responsive bidder.

UNANIMOUSLY APPROVED (21 February 2024)

Engr. Noriel C. Calpito
Vice-Chairperson

Rodrigo O. De Venecia, Jr
Member

Engr. Shayne Margie S. Abellera
Member

Romeo S. Adriano
Member

Engr. Dominic T. Agusdan
Member

Atty. Frances Louise E. Gener
Member

Atty. Ma. Luisa C. Tenedero
Chairperson

Attested by:

Apple Jane P. Aviles
Secretariat

Sharlene M. Durante
Secretariat

Approved by:

Engr. Salvador M. Royeca
General Manager