

# BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600

Document No.	ADM-PUR-F003			
Revision Date	October 29, 2019			
Revision No	02			

## **REQUEST FOR BIDS/QUOTATION (RQ)**

То:		RQ No.:	03 – 050P-D / 051P-B
	(Name of Supplier)	PR / JO No.:	050P / 051P
Contact Person:		Date of RQ:	March 11, 2024
Address:		Purpose of RC	<b>્ર</b> :
		For various B\	WD Projects use
Contact no.:		<del>-</del> -	

# NOTE: DATA REQUIRED MUST BE FILLED UP COMPLETELY. FAILURE TO INDICATE THE PRICE VALIDITY, TERMS, WARANTY PERIOD AND DELIVERY PERIOD SHALL MEAN OUTRIGHT DISQUALIFICATION OF BIDS Otv. Description U-Price

	Qty.	Description	U-Price	Total
VALIDITY DATE:	1 pc	4" Ø Gate Valve, flanged type with companion steel flanges and BNG		
day		(Please see complete specifications below)		
30 days minimum)		Approved Budget Cost: ₱27,479.00 / pc		
DELIVERY:	4 pcs	1" Ø Gate Valve, Threaded Type Class 125		
working days		(Please see complete specifications below)		
working days calendar days		Approved Budget Cost: ₱931.00 / pc		
FOB warehouse	1 pc	4" Ø Gate Valve, flanged type with combination		
	•	flanges and sealing ring and bolts & nuts		
WARRANTY		(Please see complete specifications below)		
calendar days		Approved Budget Cost: ₱23,001.00 / pc		
pon acceptance.				
		X X X X		
TERMS:				
		GATE VALVE (THREADED) SPECIFICATIONS:		
		Features: Brass Body, Non-Rising stem, Screw-over bonnet,		
		Threaded ends		
		Specifications:		
		Nominal pressure: non-shock working pressure  Max working pressure 150 psi		
		Fitting to withstand min. working pressure of 1.00		
		Thread shall be NPT		
		Water way shall unobstructed when fully opened		
		Material List		
		Handwheel: Alloy / Packing Nut: Brass		
		Bonnet: Brass / Stem: Brass Rod		
		Wedge: Brass / Body: Brass		
		Bonnet Gasket: Plastic / Packing: Teflon	,	



hhul



## BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600

# Document No. ADM-PUR-F003 Revision Date October 29, 2019 Revision No. 02

### **REQUEST FOR BIDS/QUOTATION (RQ)**

#### **GATE VALVE FLANGED TYPE SPECIFICATIONS:**

Design Code: Hydraulic test to BS 5163 (DIN3230 / DIN3352) or JIS B2043, DIN 3352, AWWA C509, BS5163

Maximum Pressure: PN16 or 16 bar

Temperature Range: -20 to 160 degree centigrade Face to Face: BS 5163 or JIS B2002, DIN 3202-F5, DIN

3202-F4, ANSI B16.10, BS 5163

End Flange: EN1092-2 (ISO 7005-2) or JIS B2212 10K, DIN

2533 PN 10/16, ANSI 150#, BS4504 PN 10/16

Tightness Test: Operating Torque Test or JIS B2003, DIN

3230, AWWA C509, BS 6755

Materials:

Body: Ductile Iron, GGG-50 to DIN 1693 (BS 2789 grade

500-7) or Ductile Iron

Wedge: Ductile Iron (DI) + NBR or Ductile Iron, GGG-50, core fully encapsulated with EPDM rubber with integral wedge nut of dezincification resistant brass, CZ 132 to BS 2874

Wedge Nut: Brass or Dezincification Resistant Brass Stem: Stainless Steel, DIN X 20 Cr 13 or Stainless Steel / Brass

Bonnet Gasket: EPDM Rubber or EPDM / NBR

Bonnet: Ductile Iron (DI) or Stainless Steel A2, sealed with

hot melt

O-Ring: NBR or EPDM / NBR

Stem Collar: Brass

Gland Flange: Ductile Iron or Ductile Iron GJS-500-7 (GGG-

50)

Dustproof Ring: NBR or EPDM / NBR

Hex Nut: Cast Iron
Overall Dimensions:

Size / DN	Length (L)	Height (H)	Width or D	Weight kgs
	mm	mm	mm	
DN100 (4")	229	334-430	200-220	26-28

Note: Not to be awarded on a one (1) lot basis.

#### This is a two (2) envelope system: Envelope "A" to contain the following, among others:

a) A refundable bid bond in the form of cash, Manager's or Cashier's check equivalent to 2% or a surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱50,000.00 and above.





#### **BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600**

ADM-PUR-F003 Document No. October 29, 2019

### REQUEST FOR BIDS/QUOTATION (RQ)

Revision Date Revision No. 02

Validity	of	f the suret	ty b	ond is	120	days	from	the
date c	of	opening	of	bids	OR	Bid	Secu	ring
Declaration regardless of the amount of bid;								

- b) Terms of payment, delivery, warranty, bid validity, and complete specifications;
- Brochure/s (Original);
- d) Proof of payment of a non-refundable fee of ₱500.00: otherwise, bids shall not be opened
- e) Certificate of Authorized Distributorship Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;
  - For bidders who have principal foreign suppliers, the BWD-BAC shall accept an **Apostilled** Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement.
  - For locally produced/manufactured products, only a certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable;
- ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);
- g) International Certificate of Warranty.

Envelope "B" to contain the bid cost per unit.

By: Supplier or Authorized Representative:	( sign over	printed name	)
--------------------------------------------	-------------	--------------	---

**April 03, 2024 Deadline of submission of bids:** 

Opening of bids:

1:30 pm

For: Prepared by: MGLamangan PURCHASING

Noted by: ATTY. M

BWD RESERVES THE RIGHT TO REJECT BIDS &/OR DECLARE A FAILURE OF BIDDING **PURSUANT TO THE PERTINENT PROVISIONS OF RA 9184** 

BWD DOES NOT ENGAGE IN SOLICITATION OF FUNDS FROM ANY INDIVIDUALS OR ENTITIES. AND WE STRONGLY ADVISE AGAINST RESPONDING TO ANY UNAUTHORIZED REQUESTS CLAIMING ASSOCIATION WITH OUR ORGANIZATION.