<u>Help</u>



Bid Notice Abstract

Invitation to Bid (ITB)

Reference Number 10718395

Procuring Entity BAGUIO WATER DISTRICT - BAGUIO CITY

Title 4" Ø Gate Valve, flanged type with combination flanges and sealing ring and bolts & nuts & 3"

Ø Gate Valve, flanged type with combination flanges and sealing ring and bolts & nuts

Area of Delivery Benguet

Solicitation Number:	03 - 063P-C	Status	Pending
Trade Agreement:	Implementing Rules and Regulations		
Procurement Mode:	Public Bidding	Associated Components	1
Classification:	Goods		
Category:	Water Service Connection Materials/Fittings	Bid Supplements	0
Approved Budget for the Contract:	PHP 295,476.00		
Delivery Period:		Document Request List	0
Client Agency:			
		Date Published	04/04/2024
Contact Person:	Ma. Luisa C Tenedero Chairperson, Bids and		
	Awards Committee BWD Compound, Utility Road Baguio City Benguet Philippines 2600 63-74-4423456 63-74-4424858 bwd.bac2021@gmail.com	Last Updated / Time	03/04/2024 07:53 AM
		Closing Date / Time	24/04/2024 13:30 PM

Description

12 pcs 4" Ø Gate Valve, flanged type with combination flanges and sealing ring and bolts & nuts

(Please see complete specifications below) Approved Budget Cost: ₱23,001.00 / pc

1 pc 3" \emptyset Gate Valve, flanged type with combination flanges and sealing ring and bolts & nuts

(Please see complete specifications below)
Approved Budget Cost: ₱19,464.00 / pc
GATE VALVE FLANGED TYPE SPECIFICATIONS:

Design Code: Hydraulic test to BS 5163 (DIN3230 / DIN3352)

or JIS B2043, DIN 3352, AWWA C509, BS5163

Maximum Pressure: PN16 or 16 bar

Temperature Range: -20 to 160 degrees centigrade

Face to Face: BS 5163 or JIS B2002, DIN 3202-F5, DIN 3202-

F4, ANSI B16.10, BS 5163

End Flange: EN1092-2 (ISO 7005-2) or JIS B2212 10K, DIN

2533 PN 10/16, ANSI 150#, BS4504 PN 10/16

Tightness Test: Operating Torque Test or JIS B2003, DIN 3230,

AWWA C509, BS 6755

Materials:

Body: Ductile Iron, GGG-50 to DIN 1693 (BS 2789 grade 500-

7) or Ductile Iron

Wedge: Ductile Iron (DI) + NBR or Ductile Iron, GGG-50, core fully encapsulated with EPDM rubber with integral wedge nut of dezincification resistant brass, CZ 132 to BS 2874 Wedge Nut: Brass or Dezincification Resistant Brass

Stem: Stainless Steel, DIN X 20 Cr 13 or Stainless Steel / Brass

Bonnet Gasket: EPDM Rubber or EPDM / NBR

Bonnet: Ductile Iron (DI) or Stainless Steel A2, sealed with hot

melt

O-Ring: NBR or EPDM / NBR

Stem Collar: Brass

Gland Flange: Ductile Iron or Ductile Iron GJS-500-7 (GGG-

50)

Dustproof Ring: NBR or EPDM / NBR

Hex Nut: Cast Iron
Overall Dimensions:
Size / DN Length (L)
mm
Height (H)
mm
Width or D
mm
Weight kgs
DN80 (3") 203 297-390 200 20-23

DN100 (4") 229 334-430 200-220 26-28

 $x \times x \times x$

Note: Not to be awarded on a one (1) lot basis.

Envelope "A" to contain the following, among others:

- a) A refundable bid bond in the form of cash, Manager's or Cashier's check equivalent to 2% or a surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of bids OR Bid Securing Declaration regardless of the amount of bid;
- b) Terms of payment, delivery, warranty, bid validity, and complete specifications;
- c) Brochure/s (Original);
- d) Proof of payment of a non-refundable fee of ₱500.00; otherwise, bids shall not be opened
- e) Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;
- For bidders who have principal foreign suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon),

except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement.

- For locally produced/manufactured products, only a certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable;
- f) ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);
- g) International Certificate of Warranty.

Envelope "B" to contain the bid cost per unit.

Created by Ma. Luisa C Tenedero

Date Created 03/04/2024

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.

© 2004-2024 DBM Procurement Service. All rights reserved.

Help | Contact Us | Sitemap