



BAGUIO WATER DISTRICT
"Serving Mankind is Serving God"
003 Purok BWD, Brgy., Marcoville, Baguio City
Tel. No. 442-4858 Fax No. 442-4858/444-7245

Document No.:	ADM-PUR-F006
Effectivity Date:	February 15, 2020
Revision No.:	00

No 035888


PURCHASE ORDER

Supplier : FANM ENTERPRISES, INC.	P.O. No. : 35888
Tel No./ Fax No. : (02) 8932-4361	Date : April 3, 2024
Address / TIN : Batasan Hills, Quezon City	PR No./Abstract No. : 03-182P-B

Gentlemen/ Madam,

Please furnish this Office the following articles subject to the terms and conditions contained herein.

Place of Delivery : <input type="checkbox"/> Pick up <input checked="" type="checkbox"/> FOB BWD Warehouse 8-12 WEEKS <input type="checkbox"/> Deliver at site	P.O. Valid Until : 30 DAYS Warranty : <input type="checkbox"/> Six months <input checked="" type="checkbox"/> One year <input type="checkbox"/> Others (Pls. Specify)
Date of Delivery : <input type="checkbox"/> Working days <input type="checkbox"/> Calendar Days upon receipt of PO	<input checked="" type="checkbox"/> 1% Retention Required <input type="checkbox"/> Performance Bond Required (5% if in check/50% if GSIS surety bond)
Delivery Term : <input type="checkbox"/> full <input type="checkbox"/> partial delivery allowed	<input checked="" type="checkbox"/> Subject to testing / inspection prior to payment Payment Term : <input type="checkbox"/> COD <input checked="" type="checkbox"/> 30 Days <input type="checkbox"/> Others (Pls. Specify)

Quantity	Unit	Description/Specifications	Unit Cost	Amount
4	pcs	"Dorot S300 Brand" 4" Ø Pressure Reducing Valve with strainer complete with companion flanges and BNG X-X-X-X-X-X-X-X-X (Please refer to the attached sheet for complete detailed specifications)	280,000.00 ₱	1,120,000.00
<div>EMAILED 4/8/24</div> <p>-Proposed installation of 4"Ø Transmission line and Distribution Lines of Zigzag Deepwell -proposed installation of 4"Ø x 457LM PVC Mainline along Crystal Cave Road Usage / Requisitioner -Proposed installation of 4"Ø x 517LM PVC Mainline and 3"Ø x 516LM PVC Distribution Lines along Outlook Drive – Lucnab c/o JJ Balangcod</p>				

Prepared by:

Checked by:

Audited by:

Recommending Approval:

Approved By:

PAUL TRAJANO

ATTY. CHANEL DOLOR D. DE GUZMAN-BITAO

LUZVIMIN G. RAMOS

ATTY. MA. LUISA C. TENEDERO

ENGR. SALVADOR M. ROYCECA

Purchasing Supervisor

Admin Division Manager

Internal Auditor

AGM-Adm./Com./Fin.

General Manager

Conforme:

7/1/24

Signature over Printed Name of Supplier

Date

Funds Available:

JELYN D. PENALES

Finance Manager

Acct. :

Operating / Maintenance Expense ☐

CAPEX ☐

Other Payables ☒






  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600	Document No.	ADM-PUR-F006
	PURCHASE ORDER (P.O)	Revision Date	February 15, 2020
		Revision No.	00




Supplier/Contractor	: FANM ENTERPRISES	Purchase Order No.	: 35888
Contact Number	: 02-8932-4361	Date	: April 3, 2024
Address / TIN	: Batasan Hills, Quezon City	PR No./Abstract No.	: 03-182P-B

Qty	Unit	Description	Unit Cost	Amount
4	pieces	"Dorot S300 Brand" 4" Pressure Reducing Valve with strainer complete with companion flanges and BNG ✓	280,200.00	1,120,000.00
		Pressure Reducing Valve Specifications:	280,000.00	
		Pressure Rating: Up to 25 bar (375 psi) Minimum system pressure 1.5 bar (22 psi) ✓	gh	
		Standard downstream pressure setting range: For 2" to 10" diameter: 30-165 psi ✓		
		End Connection: Flanged ISO- P10, ISO-PN-16 & PN-25 ✓		
		Materials:		
		Valve Body: Ductile Iron A-536 65-45-12 and/or Cast Steel WBC A-216 ✓		
		Inline control strainer: SST316 ✓		
		Pressure Gauge: SST ✓		
		Pressure Reducing Pilot Valve: SST316 ✓		
		Indicator Rod: SST316 ✓		
		Coating: High-built fusion bonded epoxy (FBE) ✓		
		Protection: External Polyester / Polyurethane ✓		
		Maintenance, disassembly, and reassembly of all the valve's component shall be made possible on-site and in-line, without the need to remove the valve from the line.		
		Simple field-adjustment pressure setting, requiring no special tools and with no system downtime		
		PRV Dimensions and Weight (Approx.):		
		PRV Size / Diameter	Length (mm)	Weight (kg)
		4" (100mm) ✓	350 ✓	37 ✓
		Note: Required length and weight should not be less than the specified measure		

Total: ₱1,120,000.00

Usage: -Proposed installation of 4"Ø Transmission line and Distribution Lines of Zigzag Deepwell
-proposed installation of 4"Ø x 457LM PVC Mainline along Crystal Cave Road
-Proposed installation of 4"Ø x 517LM PVC Mainline and 3"Ø x 516LM PVC Distribution Lines along Outlook Drive – Lucnab c/o JJ Balangcod

Prepared by:	Checked by:	Audited by:	Recommending Approval:	Approved by:
 Paul Trajano OIC-SMPO	 Atty. C.D. De Guzman-Bitao Administrative Div. Manager	 L. G. Ramos Internal Auditor	 Atty. M.L.C. Tenedero AGM Adm./Com./Fin./ICT	 Engr. Salvador M. Royeca General Manager

  	BAGUIO WATER DISTRICT Bids and Awards Committee (In-house)	Document Code: BAC_IH
		Document No. BAC_IH_F002
		Effective Date: 16 March 2020
		RESOLUTION

BIDS AND AWARDS COMMITTEE
RESOLUTION NO. 050-2024
Request for Quotation (RQ) No.01-182P-B: Pressure Reducing Valve

WHEREAS, the Baguio Water District-Bids and Awards Committee (BWD-BAC), in accordance with the provisions of Republic Act (RA) No. 9184, conducted the bidding for the procurement of four (4) pieces 4" Ø pressure reducing valve, with required specifications under RQ No. 01-182P-B, dated 29 January 2024, under a two-envelope system;

WHEREAS, the approved budget cost is Php280,000.00/piece;

WHEREAS, only **FANM ENTERPRISES, INC.** submitted its bids and during the opening of the technical bids on 27 February 2024, it was determined that the lone bidder submitted complete documentary requirements thus, its bid was rated *"passed"*;

WHEREAS, the technical proposal of **FANM ENTERPRISES, INC.** was endorsed to the Technical Working Group (TWG) for evaluation, and on 04 March 2024 its offer was rated by the TWG as *"complying"*;

WHEREAS, on 13 March 2024, its financial bid was opened and the bid as read and calculated is as follows:








NAME OF BIDDER	BID PRICE (per piece)	% VARIANCE FROM ABC	ABC (per piece)
FANM ENTERPRISES, INC.	Php280,000.00	-0-	Php280,000.00

WHEREAS, upon post-qualification, careful examination, validation, and verification of all the documents submitted by and of the financial bid of the lone complying bidder, it has been determined that **FANM ENTERPRISES, INC.** submitted complete documents and its financial bid is determined to be responsive;

NOW THEREFORE, on motion duly seconded, be it


RESOLVED, as it is hereby resolved, to recommend to the Head of the Procuring Entity (HoPE) awarding the procurement of 4 pieces of 4" Ø pressure reducing valve to **FANM ENTERPRISES, INC.** with the offered brand and specifications for being the lone calculated responsive bidder.

UNANIMOUSLY APPROVED (14 March 2024)


 Engr. Noriel C. Calpito Vice-Chairperson	 Rodrigo O. De Venecia, Jr Member	 Engr. Shayne Margie S. Abellera Member
 Romeo S. Adriano Member	 Engr. Dominic T. Agusdan Member	 Atty. Frances Louise E. Gener Member
	 Atty. Ma. Luisa E. Tenedero Chairperson	

Attested by:


Apple Jane P. Aviles
Secretariat


Sharlene M. Durante
Secretariat

Approved by:


Engr. Salvador M. Royeca
General Manager