



BAGUIO WATER DISTRICT
"Serving Mankind is Serving God"
003 Purok BWD, Brgy., Marcoville, Baguio City
Tel. No. 442-4858 Fax No. 442-4858/444-7245

Document No.:	ADM-PUR-F006
Effectivity Date:	February 15, 2020
Revision No.:	00

Nº 035947

PURCHASE ORDER

Supplier : FANM ENTERPRISES, INC.	P.O. No. : 35947
Tel No./ Fax No. : (02) 8932-4361	Date : April 18, 2024
Address / TIN : Batasan Hills, Quezon City	PR No./Abstract No. : 04-223P-D-R

Gentlemen/ Madam,

Please furnish this Office the following articles subject to the terms and conditions contained herein.

Place of Delivery : <input type="checkbox"/> Pick up <input checked="" type="checkbox"/> FOB BWD Warehouse <input type="checkbox"/> Deliver at site	P.O. Valid Until : 30 CALENDAR DAYS Warranty : <input type="checkbox"/> Six months <input checked="" type="checkbox"/> One year <input type="checkbox"/> Others(Pls. Specify)
Date of Delivery : <input type="checkbox"/> Working days 8-12 WEEKS <input type="checkbox"/> Calendar Days upon receipt of PO	<input checked="" type="checkbox"/> 1% Retention Required <input type="checkbox"/> Performance Bond Required (5% if in check/50% if GSIS surety bond)
Delivery Term : <input type="checkbox"/> full <input type="checkbox"/> partial delivery allowed	<input checked="" type="checkbox"/> Subject to testing / inspection prior to payment Payment Term : <input type="checkbox"/> COD <input checked="" type="checkbox"/> 30 Days <input type="checkbox"/> Others(Pls. Specify)




Quantity	Unit	Description/Specifications	Unit Cost	Amount
1	pc	4" Ø Hermetically Sealed Production Meter with reed switch and complete with BNG and companion steel flanges Brand: "Dorot" x x x x (Please refer to the attached sheet for complete detailed specifications)	77,784.00 ₱	<u>77,784.00</u>
<div>Usage / Requisitioner Proposed Camp 7 Zigzag DW Commissioning - Item A: Pipe Works including Skid Assembly c/o DK Eslay / JB Pamaylaon</div> <div>EMAILED 4/24/24</div>				

Prepared by: PAUL TRAJANO Purchasing Supervisor	Checked by: ATTY. CHANELL DOLOR D. DE GUZMAN-BITAO Admin Division Manager	Audited by: LUZVIMIN G. RAMOS Internal Auditor	Recommending Approval: ATTY. MA. LISA C. TENEDERO AGM-Adm./Com./Fin.	Approved By: ENGR. SALVADOR M. ROYCECA General Manager
---	---	--	--	--

Conforme: 7/17/24

Signature over Printed Name of Supplier _____ Date _____

Funds Available: JELYNID. PENALES Finance Manager	Acct. : Operating / Maintenance Expense <input type="checkbox"/> CAPEX <input checked="" type="checkbox"/> Other Payables <input type="checkbox"/>
---	---






  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600	Document No.	ADM-PUR-F006
	PURCHASE ORDER (P.O)	Revision Date	February 15, 2020
		Revision No.	00

Supplier/Contractor	: FANM ENTERPRISES ✓	Purchase Order No.	: 35947 ✓
Contact Number	: 02-8932-4361 ✓	Date	: April 18, 2024 ✓
Address / TIN	: Batasan Hills, Quezon City ✓	PR No./Abstract No.	: 04-223P-D-R ✓

Qty	Unit	Description	Unit Cost	Amount
1	pc	DOROT 4" Ø Hermetically Sealed Production Meter with reed switch and complete with BNG and companion steel flanges ✓ (please see complete specifications below)	77,784.00	77,784.00
		PRODUCTION METER SPECIFICATIONS:		
		TYPE OF METER:		
		a) Turbine type ✓		
		b) Hermetically sealed register (magnetic coupling) ✓		
		c) Sealed register ✓		
		MAIN CASING:		
		• The body casing shall be cast iron ✓		
		• Coating epoxy or polyester ✓		
		• Flange type ✓		
		• Complete with companion flange and BNG ✓		
		PERFORMANCE:		
		- The supplier shall be required to submit test results. The test parameters shall include the Maximum Flow, Nominal Flow, Transitional Flow and Minimum Flow.		
		- The BWD shall accept the water meters based on the test results submitted by the supplier. ✓		
		WORKING PRESSURE:		
		The maximum working pressure 16 bars. ✓		
		OTHER FEATURES:		
		• Meter should be designed for easy assembly and disassembly without the use of special tools or equipment and should be easy to maintain and repair. ✓		
		• Register Capacity: Minimum of six (6) digits ✓		
		• The water meter could be installed horizontally, inclined or vertically ✓		
		• The supplier must submit distributorship certification ✓		
		• Super dry type with copper can register (IP68) ✓		
		• Hermetically sealed register (magnetic coupling) ✓		
		• Low Head Loss ✓		
		• Easy maintenance of the measuring unit ✓		
		• Dial plate can be supplied in metric or imperial units ✓		
		• The totalizer has big and clear numerals ✓		
		• Maximum working temperature: 60°C ✓		
		• Register may be rotated at 360' ✓		
		• Equipped with an option for electrical output ✓		
		• Hot water meters in sizes 2" Ø to 8" Ø ✓		
		WARRANTY:		
		1 year from date of receipt against manufacturing defects ✓		

Total: ₱77,784.00

Usage: Proposed Camp 7 Zigzag DW Commissioning - Item A: Pipe Works including Skid Assembly
c/o DK Eslay / JB Pamaylaon

Prepared by:	Checked by:	Audited by:	Recommending Approval:	Approved by:
 P.M. A. Trajano OIC-SMPO	 Atty. C.D. De Guzman-Bitao Administrative Div. Manager	 L. G. Ramos Internal Auditor	 Atty. M.L.C. Tenedero AGM Adm./Com./Fin./ICT	 Engr. Salvador M. Royeca General Manager

APR 18 2024



BAGUIO WATER DISTRICT
Bids and Awards Committee
(In-house)

RESOLUTION

Document Code: BAC_IH
Document No. BAC_IH_F002
Effective Date: 16 March 2020
Revision No. 00

BIDS AND AWARDS COMMITTEE
RESOLUTION NO. 055-2024
Request for Quotation (RQ) No.02-223P-D-R:
Hermetically Sealed Production Meter

WHEREAS, the Baguio Water District-Bids and Awards Committee (BWD-BAC), in accordance with the provisions of Republic Act (RA) No. 9184, conducted the rebidding for the procurement of one (1) unit of 4" Ø Hermetically Sealed Production Meter with reed switch and complete with BNG and companion steel flanges, with required specifications under RQ No. 02-223P-D-R, dated 08 February 2024, under a two-envelope system;

WHEREAS, the approved budget cost is Php77,784.00/unit

WHEREAS, only **FANM ENTERPRISES, INC.** submitted its bids and during the opening of the technical bid on 06 March 2024, it was determined that the lone bidder submitted complete documentary requirements thus, its bid was rated "*passed*";

WHEREAS, the technical proposal of **FANM ENTERPRISES, INC.** was endorsed to the Technical Working Group (TWG) for evaluation, and on 19 March 2024 its bid was rated by the TWG as "*complying*";

WHEREAS, the financial bid of the lone complying bidder, **FANM ENTERPRISES, INC.**, was determined complying as it did not exceed the Approved Budget for the Contract:

NAME OF BIDDER	BID PRICE (per unit)	% VARIANCE FROM ABC	ABC (per unit)
FANM ENTERPRISES, INC.	Php77,784.00	-0-	Php77,784.00

WHEREAS, upon post-qualification, careful examination, validation, and verification of all the documents submitted by and of the financial bid of the lone complying bidder, it has been determined that **FANM ENTERPRISES, INC.** submitted complete documents and its financial bid is determined to be responsive;

NOW THEREFORE, on motion duly seconded, be it


RESOLVED, as it is hereby resolved, to recommend to the Head of the Procuring Entity (HoPE) awarding the procurement of 1 unit of 4" Ø Hermetically Sealed Production Meter to **FANM ENTERPRISES, INC.** with the offered brand and specifications for being the lone calculated responsive bidder.


UNANIMOUSLY APPROVED (02 April 2024)



Engr. Noriel C. Calpito
Vice-Chairperson



Rodrigo O. De Venecia, Jr.
Member


Engr. Shayne Margie S. Abellera
Member



Romeo S. Adriano
Member



Engr. Dominic T. Agusdan
Member


Atty. Frances Louise E. Gener
Member



Atty. Ma. Luisa C. Tenedero
Chairperson

Attested by:


Apple Jane P. Aviles
Secretariat


Sharlene M. Durante
Secretariat

Approved by:


Engr. Salvador M. Royeca
General Manager