



REQUEST FOR BIDS/QUOTATION (RQ)

Revision No.	02
--------------	----

RQ No.: **04 – 071P-C / 072P-F**
PR / JO No.: **071P / 072P**
Date of RQ: **April 19, 2024**
Purpose of RQ:
For various BWD projects




NOTE: DATA REQUIRED MUST BE FILLED UP COMPLETELY. FAILURE TO INDICATE THE PRICE VALIDITY, TERMS, WARRANTY PERIOD AND DELIVERY PERIOD SHALL MEAN OUTRIGHT DISQUALIFICATION OF BIDS

	Qty.	Description	U-Price	Total
VALIDITY DATE: _____ day (30 days minimum)	1 pc	2" Ø Gate Valve, threaded type (Please see complete specifications below) Approved Budget Cost: ₱2,906.00 / pc		
DELIVERY: _____ working days _____ calendar days _____ FOB warehouse	4 pcs	2" Ø Gate Valve, flanged type with companion steel flanges and BNG (Please see complete specifications below) Approved Budget Cost: ₱12,508.00 / pc		
WARRANTY _____ calendar days upon acceptance.	1 pc	4" Ø Gate Valve, flanged type with companion steel flanges and BNG (Please see complete specifications below) Approved Budget Cost: ₱27,479.00 / pc		
TERMS:		<u>GATE VALVE (THREADED) SPECIFICATIONS:</u> Features: Brass Body, Non-Rising stem, Screw-over bonnet, Threaded ends Specifications: Nominal pressure: non-shock working pressure Max working pressure 150 psi Fitting to withstand min. working pressure of 1.00 Thread shall be NPT Water way shall unobstructed when fully opened Material List Handwheel: Alloy / Packing Nut: Brass Bonnet: Brass / Stem: Brass Rod Wedge: Brass / Body: Brass Bonnet Gasket: Plastic / Packing: Teflon <u>GATE VALVE FLANGED TYPE SPECIFICATIONS:</u> Design Code: Hydraulic test to BS 5163 (DIN3230 / DIN3352) or JIS B2043, DIN 3352, AWWA C509, BS5163		

May 15, 2024

Richard

Paul Sayw

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600		Document No.	ADM-PUR-F003
	REQUEST FOR BIDS/QUOTATION (RQ)		Revision Date	October 29, 2019
			Revision No.	02

Maximum Pressure: PN16 or 16 bar
 Temperature Range: -20 to 160 degrees centigrade
 Face to Face: BS 5163 or JIS B2002, DIN 3202-F5, DIN 3202-F4, ANSI B16.10, BS 5163
 End Flange: EN1092-2 (ISO 7005-2) or JIS B2212 10K, DIN 2533 PN 10/16, ANSI 150#, BS4504 PN 10/16
 Tightness Test: Operating Torque Test or JIS B2003, DIN 3230, AWWA C509, BS 6755
 Materials:
 Body: Ductile Iron, GGG-50 to DIN 1693 (BS 2789 grade 500-7) or Ductile Iron
 Wedge: Ductile Iron (DI) + NBR or Ductile Iron, GGG-50, core fully encapsulated with EPDM rubber with integral wedge nut of dezincification resistant brass, CZ 132 to BS 2874
 Wedge Nut: Brass or Dezincification Resistant Brass
 Stem: Stainless Steel, DIN X 20 Cr 13 or Stainless Steel / Brass
 Bonnet Gasket: EPDM Rubber or EPDM / NBR
 Bonnet: Ductile Iron (DI) or Stainless Steel A2, sealed with hot melt
 O-Ring: NBR or EPDM / NBR
 Stem Collar: Brass
 Gland Flange: Ductile Iron or Ductile Iron GJS-500-7 (GGG-50)
 Dustproof Ring: NBR or EPDM / NBR
 Hex Nut: Cast Iron
 Overall Dimensions:

Size / DN	Length (L) mm	Height (H) mm	Width or D mm	Weight kgs
DN50 (2")	178	300-241	160-165	13-14
DN100 (4")	229	334-430	200-220	26-28



X X X X X

Note: Not to be awarded on a one (1) lot basis.

This is a two (2) envelope system:

Envelope "A" to contain the following, among others:

- a) A refundable bid bond in the form of cash, Manager's or Cashier's check equivalent to 2% or a surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of

 	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600		Document No.	ADM-PUR-F003
	REQUEST FOR BIDS/QUOTATION (RQ)		Revision Date	October 29, 2019
			Revision No.	02
<p>bids OR Bid Securing Declaration regardless of the amount of bid;</p> <p>b) Terms of payment, delivery, warranty, bid validity, and complete specifications;</p> <p>c) Brochure/s (Original);</p> <p>d) Proof of payment of a non-refundable fee of ₱500.00; otherwise, bids shall not be opened</p> <p>e) Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;</p> <ul style="list-style-type: none"> o For bidders who have principal foreign suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement. o For locally produced/manufactured products, only a certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable; <p>f) ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);</p> <p>g) International Certificate of Warranty.</p> <p>Envelope "B" to contain the bid cost per unit.</p>				

By: Supplier or Authorized Representative: _____ (sign over printed name)

Deadline of submission of bids: **May 15, 2024** Opening of bids: **1:30 pm**

Prepared by: PAUL TRAJANO Noted by: ATTY. MA. LUISA Z. TENEDERO ENGR. REYNALDO C. JAYCO
OIC - PURCHASING BAC IN-HOUSE BAC-TECHNICAL

**BWD RESERVES THE RIGHT TO REJECT BIDS &/OR DECLARE A FAILURE OF BIDDING
PURSUANT TO THE PERTINENT PROVISIONS OF RA 9184**

**BWD DOES NOT ENGAGE IN SOLICITATION OF FUNDS FROM ANY INDIVIDUALS OR ENTITIES, AND WE STRONGLY ADVISE
AGAINST RESPONDING TO ANY UNAUTHORIZED REQUESTS CLAIMING ASSOCIATION WITH OUR ORGANIZATION.**