	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600	Document No.	ADM-PUR-F003
	REQUEST FOR BIDS/QUOTATION (RQ)	Revision Date	October 29, 2019
		Revision No.	02

To:

(Name of Supplier)

Contact Person:

Address:

Contact no.:

RQ No.: 04 – 044P-R

PR / JO No.: 044P




Date of RQ: April 29, 2024

Purpose of RQ:
Installation of Chlorination Systems

NOTE: DATA REQUIRED MUST BE FILLED UP COMPLETELY. FAILURE TO INDICATE THE PRICE VALIDITY, TERMS, WARANTY PERIOD AND DELIVERY PERIOD SHALL MEAN OUTRIGHT DISQUALIFICATION OF BIDS				
	Qty.	Description	U-Price	Total
<div>VALIDITY DATE:</div> <div>_____ day</div> <div>(30 days minimum)</div> <div>DELIVERY :</div> <div>_____ working days</div> <div>_____ calendar days</div> <div>_____ FOB warehouse</div> <div>WARRANTY</div> <div>_____ calendar days</div> <div>upon acceptance.</div> <div>TERMS:</div>	2 sets	<div>Dosing Pump (Metering Pump), with the following specifications:</div> <div>11 l/h at 7 bars;</div> <div>230V, single phase, 60Hz;</div> <div>Solenoid Drive</div> <div>IP65 or higher</div> <div>Includes the following:</div> <div><div>• Foot valve strainer</div><div>• Injection valve, 1/2" NP</div><div>• Discharge tubing (5m)</div><div>• Suction tubing (2m)</div><div>• 20 meters 3/8" chloring tubing</div><div>• 1 unit – full voltage magnetic starter for 1/2" HP, 230V, single phase, 60Hz motor, complete with circuit breaker, magnetic contactor and thermal overload relay</div><div>• 1 unit – heavy duty stirrer / agitator, 20W – 90W, 220V, 60Hz mounted on 1 unit 220 liters capacity PE chemical tank with drain plug</div></div> <div>Approved Budget Cost: ₱106,000.00 / set</div>		
	2 sets	<div>Dosing Pump (Metering Pump), with the following specifications:</div> <div>6.8 l/h at 10 bars;</div> <div>230V, single phase, 60Hz;</div> <div>Solenoid Drive</div> <div>IP65 or higher</div> <div>Includes the following:</div> <div><div>• Foot valve strainer</div><div>• Injection valve, 1/2" NP</div><div>• Discharge tubing (5m)</div><div>• Suction tubing (2m)</div><div>• 20 meters 3/8" chloring tubing</div><div>• 1 unit – full voltage magnetic starter for 1/2" HP, 230V, single phase, 60Hz motor, complete with circuit breaker, magnetic contactor and thermal overload relay</div><div>• 1 unit – heavy duty stirrer / agitator, 20W – 90W, 220V, 60Hz mounted on 1 unit 220 liters capacity PE chemical tank with drain plug</div></div> <div>Approved Budget Cost: ₱156,000.00 / set</div>		

May 27, 2024

	2 sets	<p>Dosing Pump (Metering Pump), with the following specifications: 4.1 l/h at 16 bars; 230V, single phase, 60Hz; Solenoid Drive IP65 or higher Includes the following:</p> <ul style="list-style-type: none">• Foot valve strainer• Injection valve, 1/2" NP• Discharge tubing (5m)• Suction tubing (2m)• 20 meters 3/8" chloring tubing• 1 unit – full voltage magnetic starter for 1/2" HP, 230V, single phase, 60Hz motor, complete with circuit breaker, magnetic contactor and thermal overload relay• 1 unit – heavy duty stirrer / agitator, 20W – 90W, 220V, 60Hz mounted on 1 unit 220 liters capacity PE chemical tank with drain plug <p>Approved Budget Cost: ₱156,000.00 / set</p>		
	1 set	<p>Dosing Pump (Metering Pump), with the following specifications: 2.9 l/h at 25 bars; 230V, single phase, 60Hz; Solenoid Drive IP65 or higher Includes the following:</p> <ul style="list-style-type: none">• Foot valve strainer• Injection valve, 1/2" NP• Discharge tubing (5m)• Suction tubing (2m)• 20 meters 3/8" chloring tubing• 1 unit – full voltage magnetic starter for 1/2" HP, 230V, single phase, 60Hz motor, complete with circuit breaker, magnetic contactor and thermal overload relay• 1 unit – heavy duty stirrer / agitator, 20W – 90W, 220V, 60Hz mounted on 1 unit 220 liters capacity PE chemical tank with drain plug <p>Approved Budget Cost: ₱112,000.00 / set</p> <p>X X X X X</p> <p>Note: Not to be awarded on a one (1) lot basis.</p>		

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600	Document No.	ADM-PUR-F003
	REQUEST FOR BIDS/QUOTATION (RQ)	Revision Date	October 29, 2019
		Revision No.	02

		<p>This is a two (2) envelope system:</p> <p>Envelope "A" to contain the following, among others:</p> <p>a) A refundable bid bond in the form of cash, Manager's or Cashier's check equivalent to 2% or a surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of bids OR Bid Securing Declaration regardless of the amount of bid;</p> <p>b) Terms of payment, delivery, warranty, bid validity, and complete specifications;</p> <p>c) Brochure/s (Original);</p> <p>d) Proof of payment of a non-refundable fee of ₱1,000.00; otherwise, bids shall not be opened</p> <p>e) Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;</p> <p>i. For bidders who have principal foreign suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement.</p> <p>ii. For locally produced/manufactured products, only a certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable;</p> <p>f) ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);</p> <p>International Certificate of Warranty.</p> <p>Envelope "B" to contain the bid cost per unit.</p>		
--	--	--	--	--

By: Supplier or Authorized Representative: _____ (sign over printed name)

Deadline of submission of bids: May 27, 2024 Opening of bids: 1:30 pm

Prepared by: <i>signed</i> <u>PAUL TRAJANO</u> OIC - PURCHASING	Noted by: <i>signed</i> <u>ATTY. MA. LUISA C. TENEDERO</u> BAC IN-HOUSE	<i>signed</i> <u>ENGR. REYNALDO C. JAYCO</u> BAC-TECHNICAL
--	--	---

BWD RESERVES THE RIGHT TO REJECT BIDS &/OR DECLARE A FAILURE OF BIDDING

PURSUANT TO THE PERTINENT PROVISIONS OF RA 9184

BWD DOES NOT ENGAGE IN SOLICITATION OF FUNDS FROM ANY INDIVIDUALS OR ENTITIES, AND WE STRONGLY ADVISE AGAINST RESPONDING TO ANY UNAUTHORIZED REQUESTS CLAIMING ASSOCIATION WITH OUR ORGANIZATION.

Telefax No. (074) 442-3456 (BAC Secretariat) / (074) 442-4858 (Purchasing)