



Certificate No. CIP/5305/20/03/1123

# BAGUIO WATER DISTRICT

"Serving Mankind is Serving God"



## BID BULLETIN NO. I

### VARIOUS PIPES FOR BAGUIO WATER DISTRICT'S DEEP WELL COMMISSIONING

This bid bulletin is issued in response to the following queries of prospective bidders during the pre-bid conference held on 06 December 2024 relative to Requests for Quotation Nos. 11-215P-D/ 216P-D/ 217P-D/ 218P-D/ 219P-D/ 220P-D/ 221P-D/ 222P-D/ 223P-D and 224 P-D:

ITEM	QUERY	CLARIFICATION/ADDENDUM
40 pieces 3" Dresser Coupling (for steel and GI installation)	Is the dresser coupling and sleeve type the same or are these separate items?	Yes. Dressing coupling and sleeve type coupling is the same.
	Is companion flange with BNG a separate item? Do we need to provide additional flanges for that?	No. The requested coupling already comes with its own flange thus, companion flange with BNG should not have been included in the specifications.
	What is the plotting length? Is the standard 7 inches? Is Ductile or C.I. materials required?	Plotting length and material of coupling would depend on the proposal of the supplier as this is not indicated in the specifications provided that, it could be utilized for steel or GI installations.
80 pieces 3" Ø x 45° BI Long Elbow, Weldable	Is there no indicated schedule for elbows? What is the minimum thickness of the elbows?	There is. It is schedule 40.

Answers to other queries of the bidders are already found in the bidding documents. All specifications and requirements in the bidding documents shall remain to be in full force and effect.

For guidance and information of all concerned.

Issued this 11<sup>th</sup> day of December 2024.

#### Bids and Awards Committee:

*Signed*  
ATTY. MA. LUISA C. TENEDERO  
Chairperson

*Signed*  
GEOVANI L. PIZA  
Vice-Chairperson

*Signed*  
ENGR. JAKE D. BAWING  
Member

*Signed*  
JOANA D. CARAMÉ  
Member

*Signed*  
ENGR. JANEL J. BALANGCOD  
Member

*Signed*  
ENGR. DOMINIC T. AGUSDAN  
Member

*Signed*  
ATTY. CHELSEA S. DE LA ROSA  
Member