

BAGUIO WATER DISTRICT

BWD Compound, Utility Road, Baguio City 2600

PURCHASE ORDER (P.O)

Document No.

ADM-PUR-F006

Revision Date

October 29, 2019

Revision No.

02

Nº 036592

Supplier / Contractor	: FANM ENTERPRISES, INC.	Purchase Order No.	: 36592
Contact Number	: (02) 8932-4361	Date	: March 20, 2025
Address / TIN	: Batasan Hills, Quezon City	PR No. / Abstract No.	: 03-243P

Gentlemen / Madam,
Please furnish this Office the following articles subject to the terms and conditions contained herein.




Place of Delivery	: <input type="checkbox"/> Pick-up <input checked="" type="checkbox"/> FOB BWD Warehouse <input type="checkbox"/> Deliver at Site:	Purchase Order (PO) Valid Until:	30 DAYS
Date of Delivery	: <input type="checkbox"/> Working Days <input checked="" type="checkbox"/> Calendar Days upon receipt of PO 8-10 WEEKS	Warranty:	<input type="checkbox"/> Six Months <input checked="" type="checkbox"/> One Year <input type="checkbox"/> Others (please specify)
Delivery Term	: <input type="checkbox"/> Full <input type="checkbox"/> Partial Delivery allowed	<input checked="" type="checkbox"/> 1% Retention Required <input type="checkbox"/> Performance Bond Required (5% if in check / 50% if GSIS surety bond) <input checked="" type="checkbox"/> Subject to testing / inspection prior to payment	Payment Term: <input type="checkbox"/> COD <input checked="" type="checkbox"/> 30 Days <input type="checkbox"/> Others (please specify)

Quantity	Unit	Description / Specifications	Unit Cost	Amount
5	pcs	2" Air Release Valve Brand: "Dorot" X-X-X-X-X-X-X-X-X (Please refer to the attached sheet for complete detailed specifications)	27,527.00 ₱	137,635.00

ELIMATED
02 APR 2025

Usage / Requisitioner: For replenishment of fast moving materials to be used by R & M

Checked by:	Audited by:	Recommending Approval:	Approved by:
<div><div>signed</div><div>PAUL TRAJANO</div><div>OIC Purchasing Supervisor</div></div>	<div><div>signed</div><div>ATTY. CHANEL DOLORADO GUZMAN-BITAO</div><div>Admin. Division Manager</div></div>	<div><div>signed</div><div>ATTY. C. TENEDERO</div><div>Com./Fin.</div></div>	<div><div>signed</div><div>ENGR. SALVADOR M. ROYELA</div><div>General Manager</div></div>
Signature over Printed Name		Date	
Funds Available: <div><div>signed</div><div>JELYN M. LIGAYO</div><div>Finance Manager</div></div>		Acct.: Operating / Maintenance Expense <input checked="" type="checkbox"/> CAPEX <input type="checkbox"/> Other Payables <input type="checkbox"/>	

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600	Document No. ADM-PUR-F006
	PURCHASE ORDER (P.O)	Revision Date February 15, 2020
		Revision No. 00




Supplier/Contractor	: FANM ENTERPRISES	Purchase Order No.	: 36592
Contact Number	: 02-8932-4361	Date	: March 20, 2025
Address / TIN	: Batasan Hills, Quezon City	PR No./Abstract No.	: 03-243P

Qty	Unit	Description	Unit Cost	Amount
5	pcs	2" Air Release Valve, Brand: "Dorot"	27,527.00	137,635.00
		COMBINATION AIR VALVES SPECIFICATIONS:		
		Technical Specifications:		
		- The valve shall consist of two floats (the bottom and the upper float), -		
		the bottom float drops and allowing the trapped air to be vented -		
		through the small nozzle at the center of the top float.		
		- The float shall have a float guide on two sides.		
		- The valve shall be made of Cast Iron/ Ductile Iron with Glass Reinforced		
		Plastic (GRP) inner body.		
		- Float body shall be made of Polypropylene and it should be cylindrical/		
		trapezoid in design.		
		I.B Parts Specification of 2"Ø Combination Air Valves:		
		Description	Materials	
		Bonnet	PA6+30GF	
		Cover	D.I.	
		Flange Base	D.I.	
		Elbow	Polypropylene	
		Float	Foam PP	
		Slider	PA6+30GF	
		Seal	EPDM	
		Spacer	POM	
		Auto Seal	EPDM	
		Flat Seal	EPDM	
		O-ring	Nitrilic Rubber	
		ID Plate	Aluminum	
		Screw Hex	SST	
		Washer	SST	
		Dimensions and Weight	2" Ø	
		Height (H)	259.50 mm	
		Width (W)	214 mm	
		Thread (D)	2" (BSP / NPT)	
		Nozzle Area (A)	12.85 mm2	
		Total Width (L)	-	
		Drainage Diameter (E)	1 ½" BSP	
		Kinetic Nizzle Area (K)	908 mm	
		Flange	ISO 6/25 / ANSI 1 50	
		Weight	9 kgs.	

Total: ₱137,635.00

Usage: For replenishment of fast-moving materials to be used by R & M

Prepared by:	Checked by:	Audited by:	Recommending Approval:	Approved by:
<i>signed</i> P.A. Trajano OIC-SMPO	<i>signed</i> Atty. C.D. De Guzman-Bitao Administrative Div. Manager	<i>signed</i> L. G. Ramos Internal Auditor	<i>signed</i> Atty. M.L. Cenedero AGM Adm./Com./Fin./ICT	<i>signed</i> Engr. Salvador M. Royeca General Manager

  	BAGUIO WATER DISTRICT Bids and Awards Committee (In-house)	Document Code: BAC_IH
		Document No. BAC_IH_F002
		Effective Date: 16 March 2020
	RESOLUTION	Revision No. 00

BIDS AND AWARDS COMMITTEE RESOLUTION NO. 020-2025 Request for Quotation (RQ) No. 12-243P Air Release Valve	PURCHASING'S COPY Emailed: 14 March 2025
---	---

WHEREAS, the Baguio Water District-Bids and Awards Committee (BWD-BAC), in accordance with the provisions of Republic Act (RA) No. 9184 and its Revised Implementing Rules and Regulations (IRR), conducted the bidding for the procurement of the following, all with required specifications under RQ No. 12-243P dated 06 December 2024, under a two-envelope system of bidding but not to be awarded on a one (1) lot basis, and with the respective approved budget costs (ABCs) of:

ITEM	QUANTITY	DESCRIPTION	ABC (per piece)
1	10 pieces	1" Air Release Valve	Php14,272.00
2	10 pieces	2" Air Release Valve	Php27,527.00

WHEREAS, pursuant to *BAC Resolution Numbered 015-2025*, the Head of the Procuring Entity (HoPE) approved the recommendation of the BWD-BAC to award the aforementioned items to **FANM ENTERPRISES, INC. (FANM)** for being the lone calculated responsive bidder. *(A copy of the said Resolution is hereto attached as Annex "A")*;

WHEREAS, the end-users requested however, the deferment of the procurement of *ten (10) pieces 1" Air Release Valve and five (5) pieces 2" Air Release Valve*, which was approved by the HoPE;

NOW THEREFORE, on motion duly seconded, be it

RESOLVED, as it is hereby resolved, to defer the procurement of *ten (10) pieces 1" Air Release Valve and five (5) pieces 2" Air Release Valve* until further notice, as approved by the HoPE.

UNANIMOUSLY APPROVED (06 March 2025)

Signed
Geovani L. Piza
Vice-Chairperson

Signed
Engr. Jake D. Bawing
Member

Signed
Joana D. Caramé
Member

Signed
Engr. Janel J. Balangcod
Member

Signed
Engr. Dominic T. Agusdan
Member

Signed
Atty. Chelsea S. De la Rosa
Member

Signed
Atty. Ma. Luisa C. Tenedero
Chairperson

Attested by:

Signed
Apple Jane P. Aviles
Secretariat

Signed
Sharlene M. Durante
Secretariat

Approved by:

Signed
Engr. Salvador M. Royeca
General Manager