



Bid Notice Abstract

Invitation to Bid (ITB)

Reference Number 12024680
Procuring Entity BAGUIO WATER DISTRICT - BAGUIO CITY
Title 1 pc 3"Ø Pressure Reducing Valve & 3 pcs 2" Ø Pressure Reducing Valve (PRV)
Area of Delivery Benguet

Solicitation Number:	05-041P-C	Status	Pending
Trade Agreement:	Implementing Rules and Regulations		
Procurement Mode:	Public Bidding	Associated Components	1
Classification:	Goods		
Category:	Water Service Connection Materials/Fittings	Bid Supplements	0
Approved Budget for the Contract:	PHP 750,099.00		
Delivery Period:		Document Request List	0
Client Agency:			
Contact Person: Ma. Luisa C Tenedero Chairperson, Bids and Awards Committee BWD Compound, Utility Road Baguio City Benguet Philippines 2600 63-74-4423456 63-74-4424858 bwd.bac2021@gmail.com	Date Published		10/05/2025
	Last Updated / Time		09/05/2025 08:29 AM
	Closing Date / Time		19/05/2025 13:30 PM

Description

1 pc 3" Ø Pressure Reducing Valve (PRV)
(Please see complete specifications below)
Approved Budget Cost: ₱234,411.00 / pc

3 pcs 2" Ø Pressure Reducing Valve (PRV)
(Please see complete specifications below)
Approved Budget Cost: ₱171,896.00 / pc

Specification for Pressure Reducing Valve (PRV),
Flanged Type
Pressure Rating • Up to 25 bar (375 psi)
• Minimum system
pressure 1.5 bar (22 psi)

Standard downstream pressure setting range

• For 2" to 10" diameter: 30 – 165 psi

End Connection • Flanged ISO-P10, ISO-
PN-16 & PN-25

Materials

Valve Body • Ductile Iron A-536 65-45-12 and / or Cast Steel

WCB A-216

Inline Control Strainer • SST316

Pressure Gauge • SST

Pressure Reducing

Pilot Valve

• SST316

Indicator Rod • SST316

Coating • High built fusion bonded

epoxy (FBE)

Protection • External Polyester / Polyurethane

- Maintenance, disassembly and reassembly of all the valve's component shall be made possible on site and in-line, without the need to remove the valve from the line.
- Simple field-adjustment pressure settling, requiring special tools and with no system downtime
- PRV Dimension and Weight (Approx.): PRV Size / Diameter

Length (mm) Weight (kg)

2" (50mm) 230 12

3" (80mm) 310 22

Note: The required length and weight should not be less than the specified measure.

x x x x x

Note: Not to be awarded on a one (1) lot basis.

This is a two (2) envelope system:




Envelope "A" to contain the following; among others:

- A refundable bid bond in the form of cash, Manager's or Cashier's check equivalent to 2% or surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱ 50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of bids OR Bid Securing Declaration regardless of amount of bid;
 - Terms of payment, delivery, warranty, bid validity and complete specifications;
 - Brochure/s (Original);
 - Proof of payment of a non-refundable fee of ₱1,000.00; otherwise, bids shall not be opened
 - Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;
 - For bidders who have foreign principal suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement.
 - For locally produced / manufactured products, only a certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable;
 - ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);
 - International Certificate of Warranty.
- Envelope "B" to contain the bid cost per unit.

Created by Ma. Luisa C Tenedero

Date Created 09/05/2025

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600		Document No.	ADM-PUR-F003
	REQUEST FOR BIDS/QUOTATION (RQ)		Effectivity & Revision Date	July 7, 2023
			Revision No.	02

To: _____

 (Name of Supplier)

Contact Person: _____

Address: _____

Contact no.: _____

RQ No.: **05 – 041P-C**

PR / JO No.: **041P**

Date of RQ: **May 6, 2025**




Purpose of RQ:
 Proposed installation of distribution
 lines of Irishville Deepwell, & Purok 2
 Ambayao, Irian Deepwell
 c/o P & C Division

NOTE: DATA REQUIRED MUST BE FILLED UP COMPLETELY. FAILURE TO INDICATE THE PRICE VALIDITY, TERMS, WARRANTY PERIOD AND DELIVERY PERIOD SHALL MEAN OUTRIGHT DISQUALIFICATION OF BIDS

	Qty.	Description	U-Price	Total
<div>VALIDITY DATE:</div> <div>_____ day</div> <div>(30 days minimum)</div> <div>DELIVERY:</div> <div>_____ working days</div> <div>_____ calendar days</div> <div>_____ FOB warehouse</div> <div>WARRANTY</div> <div>_____ calendar days</div> <div>upon acceptance.</div> <div>TERMS:</div>	1 pc	<div>3" Ø Pressure Reducing Valve (PRV)</div> <div>(Please see complete specifications below)</div> <div>Approved Budget Cost: ₱234,411.00 / pc</div>		
	3 pcs	<div>2" Ø Pressure Reducing Valve (PRV)</div> <div>(Please see complete specifications below)</div> <div>Approved Budget Cost: ₱171,896.00 / pc</div>		
		<div>Specification for Pressure Reducing Valve (PRV), Flanged Type</div>		
		<div>Pressure Rating</div>	<div><ul style="list-style-type: none">Up to 25 bar (375 psi)Minimum system pressure 1.5 bar (22 psi)</div>	
		<div>Standard downstream pressure setting range</div>	<div><ul style="list-style-type: none">For 2" to 10" diameter: 30 – 165 psi</div>	
		<div>End Connection</div>	<div><ul style="list-style-type: none">Flanged ISO-P10, ISO-PN-16 & PN-25</div>	
		<div>Materials</div>		
		<div>Valve Body</div>	<div><ul style="list-style-type: none">Ductile Iron A-536 65-45-12 and / or Cast Steel WCB A-216</div>	
		<div>Inline Control Strainer</div>	<div><ul style="list-style-type: none">SST316</div>	
		<div>Pressure Gauge</div>	<div><ul style="list-style-type: none">SST</div>	
	<div>Pressure Reducing Pilot Valve</div>	<div><ul style="list-style-type: none">SST316</div>		
	<div>Indicator Rod</div>	<div><ul style="list-style-type: none">SST316</div>		

May 19, 2025




signed

  	BAGUIO WATER DISTRICT		Document No.	ADM-PUR-F003
	BWD Compound, Utility Road, Baguio City 2600		Effectivity & Revision Date	July 7, 2023
	REQUEST FOR BIDS/QUOTATION (RQ)		Revision No.	02

		Coating	• High built fusion bonded epoxy (FBE)			
		Protection	• External Polyester / Polyurethane			
		• Maintenance, disassembly and reassembly of all the valve's component shall be made possible on site and in-line, without the need to remove the valve from the line.				
		• Simple field-adjustment pressure settling, requiring special tools and with no system downtime				
		• PRV Dimension and Weight (Approx.):				
		PRV Size / Diameter	Length (mm)	Weight (kg)		
		2" (50mm)	230	12		
		3" (80mm)	310	22		
		Note: The required length and weight should not be less than the specified measure.				
		X X X X X				
Note: Not to be awarded on a one (1) lot basis.						
This is a two (2) envelope system:						
Envelope "A" to contain the following; among others:						
a) A refundable bid bond in the form of cash, Manager's or Cashier's check equivalent to 2% or surety bond callable on demand issued by a surety or insurance company duly certified by the Insurance Commission equivalent to 5% of the total approved budget cost is required for a total purchase bid amount of ₱ 50,000.00 and above. Validity of the surety bond is 120 days from the date of opening of bids OR Bid Securing Declaration regardless of amount of bid;						
b) Terms of payment, delivery, warranty, bid validity and complete specifications;						
c) Brochure/s (Original);						
d) Proof of payment of a non-refundable fee of ₱1,000.00 ; otherwise, bids shall not be opened						

May 19, 2025

signed

  	BAGUIO WATER DISTRICT BWD Compound, Utility Road, Baguio City 2600		Document No.	ADM-PUR-F003
	REQUEST FOR BIDS/QUOTATION (RQ)		Effectivity & Revision Date	July 7, 2023
			Revision No.	02
		<p>e) Certificate of Authorized Distributorship / Dealership issued by the Principal Supplier to the participating bidder (with red ribbon) if none has been submitted to the BAC in its Accreditation;</p> <ul style="list-style-type: none"> ◦ For bidders who have foreign principal suppliers, the BWD-BAC shall accept an Apostilled Certificate of Authorized Distributorship / Dealership issued by a competent authority of the host government in lieu of the Certificate of Authorized Distributorship / Dealership (with red ribbon), except for non-contracting countries to the Apostille Convention, which still require the red ribbon requirement. ◦ For locally produced / manufactured products, only a certificate of Authorized Distributorship / Dealership w/o red ribbon is required if applicable; <p>f) ISO Certificate issued to the principal supplier/participating bidder for the offered material or equipment brand name (if none has been submitted to the BAC in its Accreditation);</p> <p>g) International Certificate of Warranty.</p> <p>Envelope "B" to contain the bid cost per unit.</p>		

By: Supplier or Authorized Representative: _____ (sign over printed name)

Deadline of submission of bids: **May 19, 2025** Opening of bids: **1:30 pm**

Prepared by: *signed* **PAUL TRAJANO** OIC - PURCHASING
 Noted by: *signed* **ATTY. MA. LUISA C. TENEDERO** BAC IN-HOUSE
 signed **ENGR. REYNALDO C. JAYCO** BAC-TECHNICAL

BWD RESERVES THE RIGHT TO REJECT BIDS &/OR DECLARE A FAILURE OF BIDDING
PURSUANT TO THE PERTINENT PROVISIONS OF RA 9184
BWD DOES NOT ENGAGE IN SOLICITATION OF FUNDS FROM ANY INDIVIDUALS OR ENTITIES, AND WE STRONGLY ADVISE
AGAINST RESPONDING TO ANY UNAUTHORIZED REQUESTS CLAIMING ASSOCIATION WITH OUR ORGANIZATION.
Telefax No. (074) 442-3456 (BAC Secretariat) / (074) 442-4858 (Purchasing)

BAGUIO WATER DISTRICT

"Serving Mankind is Serving God"

STANDARD SPECIFICATION FOR 2", 2-1/2", 3", 4", 6", 8" and 10" DIAMETER PRESSURE REDUCING VALVE (PRV), FLANGED TYPE

Pressure Rating:	<ul style="list-style-type: none">● Up to 25 bar(375 psi)● Minimum system pressure 1.5bar(22psi)	
Standard downstream pressure setting range:	<ul style="list-style-type: none">● For 2" to 10"diameter : 30-165 psi	
End Connection:	<ul style="list-style-type: none">● Flanged ISO- P10, ISO-PN-16 & PN-25	
MATERIALS:		
Valve body	<ul style="list-style-type: none">● Ductile Iron A-536 65-45-12 and/or Cast Steel WCB A-216	
Inline control strainer	<ul style="list-style-type: none">● SST316	
Pressure gauge	<ul style="list-style-type: none">● SST	
Pressure reducing pilot valve	<ul style="list-style-type: none">● SST316	
Indicator rod	<ul style="list-style-type: none">● SST316	
Coating	<ul style="list-style-type: none">● High built fusion bonded epoxy (FBE)	
Protection	<ul style="list-style-type: none">● External Polyester/polyurethane	
<ul style="list-style-type: none">● Maintenance, dissassembly and reassembly of all the valve's component shall be made possible on site and in-line, without the need to remove the valve from the line.● Simple field-adjustment pressure setting, requiringno special tools and with no system downtime.		
PRV DIMENSIONS AND WEIGHT(Approx.):		
PRV SIZE/DIAMETER	LENGTH(mm)	WEIGHT (kg.)
2"(50mm)	230	12
2 1/2"(65mm)	290	13
3"(80mm)	310	22
4"(100mm)	350	37
6"(150mm)	480	80
8"(200mm)	600	157
10"(250mm)	730	245
Note: The required length and weight should not be less than the specified measure.		

Technical Working Group:

Signed

FERNANDO A. PERIA
Vice-Chairperson

Signed

RODRIGO O. DE VENEZIA, JR.
Member

Signed

VICTOR S. BAG-AYAN, JR.
Member

Signed

ALLAN A. ABAD
Member

Signed

ELISEO E. BRILLANTES
Member

Signed

MARCO G. DELA CRUZ
Member

Recommending Approval:

Signed

GUILLERMO V. LUCERO
Chairperson

Approved by:

Signed

SALVADOR M. ROYECÁ
General Manager